

Shutdown Proposed for the month of March 2023																																				
Sl. No.	Name of Element	Mar-23																															Time	Reason	Category	
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31				
SHUTDOWNS PROPOSED BY PGCIL																																				
132kV Transmission lines																																				
1	132KV R C Nagar- Agarfala - II TL																																0700 Hrs to 1600 Hrs	AMP of 132KV R C Nagar Bay-II at 132KV 79Tlla S/S	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 kV R C Nagar- Kumarghat line and 132 kV R C Nagar - P K Bari I & II. Consent from SLDC Tripura required.
2	132KV BADARPUR - KOLASIB TL																																0700 Hrs to 1600 Hrs	AMP of Badarpur Bay at Kolasib end and TL works at Badarpur end	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 kV Aizawl-Kolasib, 132 kV Aizawl - Melriat line, 132 kV Aizawl - Tipamukh-Jiribam link and 132 kV Aizawl - Kumarghat line. Consent from SLDC Mizoram required.
3	132KV AIZAWL-LUANGMUAL (P&E, Mizoram)																																0900Hrs to 1400Hrs	Installation and Commissioning of new P543 Line Differential Relay for Aizawl Bay at Luangmual S/S (P&E, Mizoram) under GIS Upgradation project of Aizawl S/S	Existing system improvement related shutdown.	SD may be availed. Flow in 132 kV Melriat (PG) - Zensabark line to be kept within 74 MW. However, the same can be increase if there is no low voltage issues observed in Mizoram Power System. Consent from SLDC Mizoram required.
4	132KV AIZAWL-MELRIAT (P&E, Mizoram)																																0700Hrs to 1800Hrs	Installation and Commissioning of new P543 Line Differential Relay for Aizawl Bay at Luangmual S/S (P&E, Mizoram) under GIS Upgradation project of Aizawl S/S	Existing system improvement related shutdown.	SD may be availed. 132 kV Badarpur - Kolasib - Aizawl line, 132 kV Jiribam - Tipamukh - Aizawl link, 132 kV Kumarghat - Aizawl line to be kept in service. Consent from SLDC Mizoram required.
5	132KV AIZAWL - KOLASIB (P&E, Mizoram)																																0700Hrs to 1800Hrs	Installation and Commissioning of new P543 Line Differential Relay for Aizawl Bay at Luangmual S/S (P&E, Mizoram) under GIS Upgradation project of Aizawl S/S	Existing system improvement related shutdown.	The SD may be availed subject to availability of 132 kV Badarpur-Kolasib, 132 kV Aizawl - Melriat line, 132 kV Aizawl - Tipamukh-Jiribam link and 132 kV Aizawl - Kumarghat line. Consent from SLDC Mizoram required.
6	132KV S/C AIZAWL-KUMARGHAT TL																																0700Hrs to 1800Hrs	RECTIFICATION OF S/D NATURE DEFECTS IDENTIFIED DURING PATROLLING OF TRANSMISSION LINE.	Normal Maintenance related shutdown.	SD may be availed. 132 kV Badarpur - Kolasib - Aizawl line, 132 kV Jiribam - Tipamukh - Aizawl link, 132 kV Melriat - Aizawl line to be kept in service. Consent from SLDC Mizoram required.
7	132kV Khlhiehat Khandong - 1 TL																																0800 Hrs to 1600 Hrs	LBB relay retrofiting	Existing system improvement related shutdown.	SD may be availed with consent from SLDC Assam and NEEPCO. No overloading issue in 132 kV Khlhiehat Khandong II TL as 132 kV Jiribam - Halfong line is kept open.
8	132kV Khlhiehat Badarpur - 1 TL																																0800 Hrs to 1600 Hrs	removal of balance arching horn from the line	Existing system improvement related shutdown.	At present, due to low generation at Meghalaya power system and outage of 132 Khandong-Kopili link, 132 kV Harlong-Jiribam line and 132 kV Loktak-Jiribam line, the Meghalaya power system is not N-1 compliant. The SD may only be availed after restoration of Khandong-Kopili link and/or other above lines under outage.
9	132kV Loktak - Jiribam TL																																CSD 0900Hrs to 1600Hrs	For conductor restringing to HTLS under NERSS project	Construction Related Shutdown	SD may be availed. FTC to be processed.
10	132 KV Balipara - Khupi TL																																0800 Hrs to 1600 Hrs	AMP of Khupi Bay	Normal Maintenance related shutdown.	SD may be availed. Consent from SLDC, Arunachal Pradesh may be obtained as Khupi, Teng, Dibahi will be out of service when the shutdown is availed.
11	132kV BNC Pavoi - 1 TL																																0700 Hrs to 1500 Hrs	Installation of Line differential relay at both ends	Existing system improvement related shutdown.	SD may be availed subject to availability of 132 kV BNC-Pavoi 2 TL. Loads in Pavoi, Golpur, Majuli, Lakhimpur, Dimaaji to be kept within the allowable loading of 132 kV BNC-Pavoi 2 TL, which is 84 MVA. Consent from SLDC Assam may be obtained.
12	132kV BNC Pavoi - 2 TL																																0700 Hrs to 1500 Hrs	Installation of Line differential relay at both ends	Existing system improvement related shutdown.	SD may be availed subject to availability of 132 kV BNC-Pavoi 1 TL. Loads in Pavoi, Golpur, Majuli, Lakhimpur, Dimaaji to be kept within the allowable loading of 132 kV BNC-Pavoi 1 TL, which is 84 MVA. Consent from SLDC Assam may be obtained.
13	132kV Badarpur-Silchar-2 TL																																0800Hrs to 1200Hrs	Firmware upgradation of Micom P442 relay	Existing system improvement related shutdown.	At present, due to low generation at Meghalaya power system and outage of 132 Khandong-Kopili link, 132 kV Harlong-Jiribam line and 132 kV Loktak-Jiribam line, the Meghalaya power system is not N-1 compliant. The SD may only be availed after restoration of Khandong-Kopili link and/or other above lines under outage.
14	132kV Badarpur-Panchgram (Badarpur/AEGL) TL																																0800Hrs to 1200Hrs	Firmware upgradation of Micom P442 relay	Existing system improvement related shutdown.	At present, due to low generation at Meghalaya power system and outage of 132 Khandong-Kopili link, 132 kV Harlong-Jiribam line and 132 kV Loktak-Jiribam line, the Meghalaya power system is not N-1 compliant. The SD may only be availed after restoration of Khandong-Kopili link and/or other above lines under outage.
15	132kV Badarpur-Jiribam TL																																0800Hrs to 1200Hrs	Firmware upgradation of Micom P442 relay	Existing system improvement related shutdown.	The SD may be availed subject to availability of 132 kV Aizawl-Kolasib-Badarpur link, 132 kV Silchar-Badarpur DC and 132 kV Badarpur-Karriganj-Kumarghat link.
Mar-23																																				
16	132kV Karimganj-Kumarghat TL																																0800Hrs to 1600Hrs	Infringement clearing works at span loc 194-195, 234-240	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 kV Badarpur Karimganj line. Consent to be taken from SLDC, Assam
17	132kV Mokokchung - Mokokchung - 1 TL																																0800Hrs to 1600Hrs	AMP of Mokokchung bay at state end	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 kV Mokokchung - Mokokchung - 2 & 132 kV Doyang-Mokokchung line. Consent from SLDC Nagaland to be taken
18	132kV Mokokchung - Mokokchung - 2 TL																																0800Hrs to 1600Hrs	AMP of Mokokchung bay at state end	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 kV Mokokchung - Mokokchung - 1 & 132 kV Doyang-Mokokchung line. Consent from SLDC Nagaland to be taken
19	132kV Silchar - Melriat - 1 TL																																0800Hrs to 1600Hrs	Insallation of DTPC panel	Existing system improvement related shutdown.	SD may be availed subject to availability of 132 kV Silchar - Melriat - 2 line.
20	400kV Palatana-SMNagar(STS) line																																0600Hrs to 1530Hrs	for Construction works of LILO of 400kV D/C Palatana-SMNagar line at SMNagar(TSECL) SS under project-NERSS-XIV	Construction Related Shutdown	SD may be availed. SPS related to tripping of 400 kV Silchar - Palatana D/C to be kept in service. Also, 400 kV Silchar - PKBari - SMNagar link to be kept in service.
21	132kV Ziro - Ranganadi TL																																0800Hrs to 1600Hrs	for commissioning of ABB make PLCC panels	Existing system improvement related shutdown.	SD may be availed after consent from SLDC, AP is received as Ziro- Daporijo-Along-Pasighat-Rong-Tezu-Namsai link (with loads) will be out due to the shutdown.
22	132kV Kumarghat- Karimganj TL																																CSD 0900Hrs to 1600Hrs	for leakage attending of Bus Duct chamber (by M/s Takai as part of Construction defect rectification)	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 132 kV Badarpur Karimganj line. Consent to be taken from SLDC, Assam
23	132kV Dimapur- Imphal Line																																0700Hrs to 1800Hrs	Construction related- for GI Bus Duct erection work under NERSS-XIII at Imphal end.	Construction Related Shutdown	SD may be deferred until revival of 132 kV Loktak - Jiribam(PG) line. Consent from SLDC, Manipur may be taken
24	A/R of 132kV Pasighat-Roing TL																																0700Hrs to 1700Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
25	A/R of 132kV AIZAWL-TIPAIMUKH																																0700Hrs to 1700Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
26	A/R of 132 KV KHUPI - KIMI LINE																																0700Hrs to 1700Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
27	A/R of 132 KV BALIPARA - KHUPI LINE																																0700Hrs to 1700Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
Mar-23																																				
220kV Transmission lines																																				
28	220kV Mariani (PG)- Mariani (AEGL) line																																CSD 0800Hrs to 1600Hrs	To carry out stringing work for anchor tower	Construction Related Shutdown	SD may be availed. Flowgate of Upper Assam to be maintained below 230 MW during the SD period. N-1 considered 220 kV AGBPP - Mariani (AS) line. Consent from SLDC Assam to be taken.
29	220kV New Mariani - Mokokchung - 2 TL																																0800Hrs to 1600Hrs	for jumper lightning works	Normal Maintenance related shutdown.	SD may be availed subject to availability of 220 kV New Mariani - Mokokchung 1 TL.
30	220kV Misa - Samaguri - 2																																0800Hrs to 1600Hrs	AMP of Bay Equipments	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 220kV Misa - Samaguri-1, 220 kV Balipara- Sonab-Samaguri link and 220 kV Azara - Sarania D/C. Generation from Langpi is to be maximised during the SD period.
31	A/R of 220 KV Misa - Dimapur-1 TL																																0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode

Sl. No.	A/R of 220 KV Misa - Dimapur -2 TL	Mar-23																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31				
32	A/R of 220 KV Misa - Dimapur -2 TL	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
33	A/R of 220KV Misa-Kopili #1	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
34	A/R of 220KV Misa-Kopili #2	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
400kV Transmission lines		[Green]																																		
35	400 KV Balipara - Misa-1 TL	[Red]																															0800Hrs to 1600Hrs	Shut down required for OPGW installation at river crossing due to very long span	Existing system improvement related shutdown.	SD may be deferred until 220 LV BTPS-Salakati D/C are in service.
36	400 KV Balipara - Misa-2 TL	[Red]																															0800Hrs to 1600Hrs	Shut down required for OPGW installation at river crossing due to very long span	Existing system improvement related shutdown.	SD may be deferred until 220 LV BTPS-Salakati D/C are in service.
37	400kV Bongaigaon Balipara # 3 along with LR	[Red]																															0800Hrs to 1600Hrs	Modification on OTI/WTL PRV circuit to prevent maloperation of the equipment	Existing system improvement related shutdown.	SD may be availed subject the availability of 400 kV Bongaigaon Balipara I, II and IV
38	400kV Misa - New Mariani - 1 TL	[Red]																															0800Hrs to 1600Hrs	Insulator replacement works at critical locations	Normal Maintenance related shutdown.	SD may be availed. 400 kV Misa - New Mariani II to be kept in service.
39	400kV Silchar_Imphal 1 & 2 TL	[Red]																															CSD 0900Hrs to 1700Hrs	for Shifting of DE Tower, Erection of Gantry & Commissioning of Line Reactors along with it's bays under NERSS-XI.	Construction Related Shutdown	Considering N-2 contingency; outage of both circuits of 400 kV Imphal - New Kohima D/C Under the above scenario, power can be imported by Manipur Power System via these interconnections: 132 kV Imphal - Dairapur line 132 kV Karong - Kohima line The maximum power that can be drawn by the above two connections is (50 + 50) = 100 MW. The above restriction is due to restriction in 132 kV Karong - Kohima line within 50 MW and low voltage of 121 kV at terminal stations. Therefore, load restriction has to be taken by Manipur Power System
40	A/R of 400 KV Misa - Balipara -1 TL	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
41	A/R of 400 KV Misa - Balipara -2 TL	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
42	A/R of 400kV New Mariani - Misa - 1 TL	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
43	A/R of 400kV New Mariani - Misa - 2 TL	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
44	A/R of 400kV Balipara - Bongaigaon # 1 TL	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
45	A/R of 400kV Balipara - Bongaigaon # 2 TL	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
46	A/R of 400kV D/C Silchar-Palatana	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
47	A/R of 400kV Silchar-Bymihat TL	[Red]																															0700Hrs to 1800Hrs	Auto reclosure to be kept at non auto mode for OPGW works	Existing system improvement related shutdown.	A/R may be kept in Non-Auto Mode
220kV Dimapur SS		[Green]																																		
48	220/132kV, 100MVA ICT-3 at Dimapur	[Red]																															CSD 0800Hrs to 1600Hrs	Replacement of Bushing CT Terminal Plate	Normal Maintenance related shutdown.	The SD may be availed subject to availability of 220/132kV ICT II and I at Dimapur.
49	132kV Bus Coupler - 1 at Dimapur 132kV Main Bus - 1 at Dimapur 132kV Dimapur - Kohima TL 132kV Dimapur - Dimapur 2 TL	[Red]																															0800Hrs to 1600Hrs	SF6 gas filling in Main Bus-I, for Latent Defect identification noted in Current imbalance.	Normal Maintenance related shutdown.	SD may be availed. 132 kV Dimapur - Dimapur I Line to be kept in service. As the Main Bus I at Dimapur will be under shutdown, all the remaining elements are to be kept in Main II Bus. Consent from SLDC Nagaland to be obtained.
132 kV Badarpur SS		[Red]																																		
50	132kV Main Bus at Badarpur	[Red]																															0800Hrs to 1600Hrs	AMP of Bus	Normal Maintenance related shutdown.	At present, due to low generation at Meghalaya power system and outage of 132 Khandong-Kopili link, 132 kV Hatlong-Jiribam line and 132 kV Lotak-Jiribam line, the Meghalaya power system is not N-1 compliant. The SD may only be availed after restoration of Khandong-Kopili link and/or other above lines under outage.
51	132kV Transfer Bus Coupler bay at Badarpur	[Red]																															0800Hrs to 1600Hrs	AMP of Bay Equipments	Normal Maintenance related shutdown.	SD may be availed.
132kV Melriat SS		[Red]																																		
52	15MVAR Bus Reactor at Melriat	[Red]																															1000Hrs to 1600Hrs	Modification on OTI/WTL PRV circuit to prevent maloperation of the equipment	Existing system improvement related shutdown.	SD may be availed. About 1-2 kV change in voltage at Melriat Bus is observed.
220kV Mokokchung SS		[Red]																																		
53	220kV Bus Coupler at Mokokchung	[Red]																															0800Hrs to 1600Hrs	AMP of Bay Equipments	Normal Maintenance related shutdown.	SD may be availed provided no outage of elements.
54	220/132kV 30MVA ICT - 1 at Mokokchung	[Red]																															0800Hrs to 1600Hrs	AMP of ICT	Normal Maintenance related shutdown.	SD may be availed. Other 2 ICTs to be in service. Consent from SLDC Nagaland is to be taken.
55	220/132kV 30MVA ICT - 2 at Mokokchung	[Red]																															0800Hrs to 1600Hrs	Modification on OTI/WTL PRV circuit to prevent maloperation of the equipment	Existing system improvement related shutdown.	SD may be availed. Other 2 ICTs to be in service. Consent from SLDC Nagaland is to be taken.
56	220/132kV 30MVA ICT - 3 at Mokokchung	[Red]																															0800Hrs to 1600Hrs	Modification on OTI/WTL PRV circuit to prevent maloperation of the equipment	Existing system improvement related shutdown.	SD may be availed. Other 2 ICTs to be in service. Consent from SLDC Nagaland is to be taken.
220kV Salakati SS		[Green]																																		
57	220/132kV ICT - 2 Main bay (HV side) at Salakati	[Red]																															0700Hrs to 1600Hrs	AMP of Bay Equipments	Normal Maintenance related shutdown.	SD may be availed provided no outage of ICT-2
58	220/132kV ICT - 2 Main bay (LV side) at Salakati	[Red]																															0700Hrs to 1600Hrs	AMP of Bay Equipments	Normal Maintenance related shutdown.	SD may be availed provided no outage of ICT-2
400kV Silchar SS		[Red]																																		
59	400kV 63MVAR Bus Reactor-1 at Silchar	[Red]																															0900Hrs to 1500Hrs	Modification on OTI/WTL PRV circuit to prevent maloperation of the equipment	Existing system improvement related shutdown.	SD may be availed. About 2 kV voltage change is observed in Silchar S/s

SN	Name of Element	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	Time	Reason	Category																																						
	Mar-23																																																																								
35	132 KV Agartala - Bodhjungnagar line																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed.																																
36	132 KV Baramura - Gamaitla																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed.																																
37	132 KV Baramura - Jirania																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed.																																
38	132 KV Rokhia to Agartala L-1																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. Combined Generation of Monarchak and Rokhia Generation to be kept within 75 MW.																																
39	132KV Rokhia to Agartala L- II																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. Combined Generation of Monarchak and Rokhia Generation to be kept within 75 MW.																																
40	132 KV Surjamaninagar (ISTS)- Bodhjungnagar																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. 132 kV Palatana - Surjamaninagar line, 132 kV PK Bari - PK Bari line and 132 kV PK Bari - Ambassa line to be kept in service.																																
41	132 KV Baramura - Jirania																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed.																																
42	132 KV Grid SS, 79 Tilla (Section - Z) with 132 KV Agartala - Dhalebil and 132 KV Agartala -R.C.Nagar L1.																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed.																																
43	132 KV Surjamaninagar (ISTS)- Bodhjungnagar																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. 132 kV Palatana - Surjamaninagar line, 132 kV PK Bari - PK Bari line and 132 kV PK Bari - Ambassa line to be kept in service.																																
44	132 KV Monarchak - Udaipur																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. Generation of Monarchak to be kept within 75 MW to limit the flow in 132 kV Monarchak - Rokhia line within 65 MW.																																
45	132 KV Rokhia - Monarchak																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. SPS at Monarchak to be kept OFF. Generation at Monarchak to be kept within 70 MW to limit the flow in 132 kV Monarchak - Udaipur line within 65 MW.																																
46	132 KV Jirania - Baramura																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed.																																
47	132 KV Surjamaninagar (TSECL) - Surjamaninagar (ISTS)																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. 132 kV SMNagar(ISTS) - Bodhjungnagar line, 132 kV PK Bari - PK Bari line, 132 kV PK Bari - Ambassa line, 132 kV Palatana - Surjamaninagar line to be kept in service																																
48	132 KV Ambassa - PK Bari(ISTS)																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. 132 kV SMNagar(ISTS) - Bodhjungnagar line, 132 kV SMNagar(ISTS) - SMNagar line, 132 kV PK Bari - PK Bari line, 132 kV Palatana - Surjamaninagar line to be kept in service.Other lines connected to Ambassa to be kept in service.																																
49	132 KV Surjamaninagar (ISTS) - Bodhjungnagar																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. 132 kV SMNagar(ISTS) - SMNagar line, 132 kV PK Bari - PK Bari line, 132 kV PK Bari - Ambassa line, 132 kV Palatana - Surjamaninagar line to be kept in service																																
50	132 KV P.K Bari - Dharmanagar																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. 132 kV Dharmanagar - Dullavchera - Haikandi link are to be kept in service.																																
51	132 KV Baramura - Gamaitla line																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed.																																
52	132 KV Dharmanagar - Dullavchera																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed. 132 kV PKBari - Dharmanagar line and 132 kV Haikandi - Dullavchera line are to be kept in service																																
53	132 KV Surjamaninagar - Bodhjungnagar																																					(9 am to 4 pm)	Pre-Monsoon maintenance	Normal Maintenance related shutdown.	SD may be availed.																																
	Mar-23																																																																								
	SHUTDOWNS PROPOSED BY INDIGRID																																																																								
1	400 KV BR 1 PK Bari																																						0900 to 1400 Hrs	AMP of Bus Reactor-1	Normal Maintenance related shutdown.	SD may be availed. About 3 kV voltage change is expected at 400 kV PK Bari Bus.																															
2	400 KV BR 2 PK Bari																																						0800 to 1600 Hrs	AMP of Bus Reactor-2	Normal Maintenance related shutdown.	SD may be availed. About 3 kV voltage change is expected at 400 kV PK Bari Bus.																															
3	MAIN BAY (104) OF A 132KV-BUS COUPLER @SURAJMANINAGAR (STERLITE) - 132KV																																						0900 to 1800 Hrs	For AMP Work	Normal Maintenance related shutdown.	SD may be availed.																															
4	400KV-ALIPURDUAR (PG)-BONGAIGAON-1																																						0700 to 1700 Hrs	Annual outage for SD defect rectification	Normal Maintenance related shutdown.	SD may be availed. Other circuit to be kept in service.																															
5	400KV-ALIPURDUAR (PG)-BONGAIGAON-2																																						0700 to 1700 Hrs	Annual outage for SD defect rectification	Normal Maintenance related shutdown.	SD may be availed. Other circuit to be kept in service.																															
6	400KV D/C Sihar - Msa Line																																					CSD 0700 to 1300 Hrs	Permanent restoration of 400KV Sihar - Msa Line (400kV SM line) through New AP-229N & Destraining of 400kV SM line which was charged through ERS	Construction Related Shutdown	SD may be availed.																																
	Mar-23																																																																								
	SHUTDOWNS PROPOSED BY MEGHALAYA																																																																								
1	132KV Umfru Bus bar																																						0900 to 1500 Hrs	Checking, tightening or replacement of terminal equipments, clamps & accessories, isolator contacts, conductors of bus side etc.	Normal Maintenance related shutdown.	Study not done due to late submission																															
	APPROVED																																																																								
	REJECTED																																																																								