



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/COM/ REA/2022/ **1846-1892**

Dt. 19 January 2023

सेवा में / To,

संलग्न सूची के अनुसार

As per list enclosed.

Sub: Certification of Ramping Performance for Coal/Lignite ISGS of NER for December 2022 for FY 2022-23

Sir,

The statement of summary of ramping performance of coal/lignite ISGS of NER for the month of November 2022 as furnished by NERLDC vide letter no. NERLDC/RA/2022-23/RampCert/9 dated 19-01-2022 is certified as enclosed. This is prepared in accordance with the Regulation 30 of CERC (Terms and Conditions of Tariff) Regulations, 2019 and the Revised detailed guidelines for assessment of ramping capability of thermal ISGS issued by NLDC vide letter dated 30.12.2020.

Constituents may send their observation/ comments, if any on the same within 15 days from the date of issue of this statement.


Encl.: As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल / S. M. Aimol)
निदेशक / Director
अधीक्षण अभियंता / Superintending Engineer
वाणिज्य / Commercial

List of Addressees:


1. CMD, TSECL, Bidyut Bhawan, Agartala – 799 001
2. Director (Distribution), MePDCL, Lumjingshai, S.R. Road, Shillong – 793 001
3. Engineer-in-Chief (P&E), P&E Dept., Govt. of Mizoram, Aizawl – 796 001
4. Chief General Manager (Comml), APDCL, Bijulee Bhawan, Paltan Bazar, Guwahati – 781 001
5. Chief Engineer (Comm), Dept. of Power, Govt. of Arunachal Pradesh, Itanagar – 791 111
6. Managing Director, MSPDCL, Keishampat, Imphal – 795001
7. E-in-C, Dept. of Power, Govt. of Nagaland, Kohima – 797 001
8. Chief Engineer, Loktak HE Project, Vidyut Vihar, Komkeirap, Manipur – 795 124
9. Executive Director (Comml.), NEEPCO Ltd., Lower New Colony, Shillong – 793 003
10. Executive Director, NERTS, POWERGRID, Lapalang, Shillong – 793 006
11. Managing Director, OTPC, Core 4 & Central, 10th Floor, SCOPE Minar, Laxmi Nagar, Delhi – 110092
12. GM (Comml.), NTPC, 3rd Floor OLIC building, Plot No.N.17/2, Nayapalli, Bhubaneswar-12
13. CE (G. M.), CEA, SewaBhawan, R.K.Puram, New Delhi – 110 066.
14. E. D., NERLDC, Lower Nongrah, Dongtiah, Lapalang, Shillong - 6.
15. C.G.M (SLDC) AEGCL, Kahelipara, Guwahati.
16. Gen. Manager (Comml.), NHPC Ltd., NHPC Office complex, Sector –33, Faridabad-121003.
17. C.G.M (Commercial) APDCL, Bijulee Bhawan, Paltan Bazar, Guwahati - 781 001.
18. General Manager, Ranganadi HEP, NEEPCO, Yazlee, Ar. Pradesh
19. Project Manager, Doyang HEP, NEEPCO, Nagaland
20. Project Manager, AGBPP, NEEPCO Ltd., No. –III, Vill. Bokuloni, Dibrugarh, Assam.
21. Project Manager, AGTPP, NEEPCO Ltd., Ramchandranagar, Agartala, Tripura West- 799008.
22. Dy. G. M (Elect.), Kopili HEP, NEEPCO Ltd., Umrangso, N.C. Hills, Assam.
23. Supdt. Engr. (System Management) MeECL, Lumjingshai, Short Round Road, Shillong.
24. ED (Comml), MSPDCL, Secure Office Building Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
25. Executive Engineer, MSLDC, P & E Dept., Chaltlang, Aizawl- 796012.
26. Supdt. Engr. Dimapur Sub-station Deptt. of Power, Govt.of Nagaland, Dimapur.
27. Dy. G. M. (Commercial) NERTS, Lower Nongrah, Dongtiah, Lapalang, Shillong - 6.
28. Dy. General Manager (ER), POWERGRID, Boring Road, Alankar Place, Patna - 800 001
29. DGM (Comml), OTPC, 6th Floor, IFCI Tower, 61 Nehru Place, New Delhi – 110 019
30. AGM (Comml.), NTPC, 3rd Floor OLIC building, Plot No.N.17/2, Nayapalli, Bhubaneswar-12
31. AGM (Comml.), NTPC, Bongaigaon Thermal Power Project, P.O Salakati, Kokrajhar-783369
32. Addl. General Manager,Comml & Sys.Opn., TSECL,Banamalipur,Agartala.-799001.
33. Ex. Engr., SLDC, Deptt. of Power, Itanagar, Ar. Pradesh – 791 111
34. CEO, NVVNLtd., 7th Floor, Scope Complex, Lodhi Road, N.Delhi- 110 003
35. Power Trading Corpn. of India Ltd., 2nd Floor, NBCC Tower, 15-Bhikaji Cama Place, New Delhi – 66.
36. DGM (Power Trading), Adani Exports Ltd, 13 Palam Marg, Vasant Vihar, New Delhi- 110057.
37. ED, TPTCL, Block 'A', 34, Sant Tukaram Road, Carnac Bunder, Mumbai-400 009.
38. Member Secretary, NRPC,18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, NewDelhi-110016.
39. Member Secretary, ERPC,14, Golf Club Road, Kolkata- 700 033.
40. Member Secretary, WRPC, Plot No F-3, MIDC Area, Opp Seepz, Marol, Andheri (E), Mumbai-400 093.
41. Member Secretary, SRPC, 29, Race Course Road, Bangalore- 560009.
42. Lanco Electric Utility Limited, LANCO House,141, Avenue,8, Banjara Hills, Hyderabad-500 034
43. Reliance Energy Trading Ltd., Reliance Energy Centre, Santa Cruz (E), Mumbai-400 055
44. Vice President, Indian Energy Exchange Limited, 10th Floor, B Wing, Statesman House,
45. Barakhamba Road, Connought Place, New Delhi - 110 001.
46. LANCO Electric Utility Ltd, Plot No 229, Udyog Vihar, Phase-1, Gurgaon, Haryana – 122 016.
47. RPTCL, Agrawal House, 2, St. George's Gate Road, 6th Floor, Kolkata – 700 022.


(एस. एम. आइमोल / S. M. Aimol)
निदेशक / Director

अधीक्षण अभियंता / Superintending Engineer
वाणिज्य / Commercial

NORTH EASTERN REGIONAL POWER COMMITTEE

Ramp Performance of Thermal Power Stations for Month										December 2022
Number of months in computation (M):										09
Station	Total no. of Time Blocks (Tm)	No. of Time Blocks Where Declared Ramp Up & Down rate $\geq 1\%(T_d)$	Td/Tm	No. of time blocks where scheduled ramp $\geq 1\%/min$ (D)	Out of (D), no. of time blocks where actual ramp \geq scheduled ramp (E)	Out of (D), no. of time blocks where actual ramp $\geq 1\%/min$ (F)	Average actual ramp rate during blocks when scheduled ramp $\geq 1\%/min$ (%/min) (AARR)	E/D	F/D	Recommended change in RoE(%)
BGTPP	26113	25681	0.98	1778	1435	1498	0.99	0.81	0.84	0


 (एस.एम.आइमोल/S.M.Aimol)
 निदेशक/Director
 उ.पु.क्षेत्र/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong