



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2023/2487-2509

Dt:11th July, 2023

सेवामें / To,

संलग्नसूचीकेअनुसार
As per list enclosed.

Sub: Reactive Energy Account under ABT regime-for the period 29.05.2023 to 02.07.2023 (5 weeks)- Reg.

सर/मैडम,
Sir/Madam.

The statement of Reactive Energy account giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 29.05.2023 to 02.07.2023 (5 weeks) is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 16.5 Paise/KVARH w.e.f from 1st April 2023, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,

(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षणअभियंता/ Superintending Engineer

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtiah Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtiah, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.



(एस. एम. आइमोल/ S. M. Aimol)

निदेशक / Director

अधीक्षण अभियंता/ Superintending Engineer


Reactive Energy (VArH) Charge Statement
for the period 5/29/2023 to 6/4/2023

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

| BENEFICIARY | AMOUNT PAYABLE TO POOL(Rs.) | AMOUNT RECEIVABLE FROM POOL (Rs.) |
|--------------------|------------------------------------|--|
| ARUNACHAL PRADESH | 6,060 | 0 |
| ASSAM | 0 | 94,601 |
| MANIPUR | 62,418 | 0 |
| MEGHALAYA | 0 | 228,336 |
| MIZORAM | 15,099 | 0 |
| NAGALAND | 4,681 | 0 |
| TRIPURA | 0 | 539 |

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

| RECEIVABLE BENEFICIARY | FROM BENEFICIARY | AMOUNT RECEIVABLE (Rs.) |
|-------------------------------|-------------------------|--------------------------------|
| ASSAM | MEGHALAYA | 4,386 |
| ASSAM | TRIPURA | 2,368 |
| MANIPUR | NAGALAND | 0 |
| MEGHALAYA | ASSAM | 0 |
| NAGALAND | MANIPUR | 0 |
| TRIPURA | ASSAM | 0 |



(एस.एम. आइमोल/S.M.Aimol)
निदेशक/Director
उप-क्षेत्रीय/Min. of Power
विद्युत मंत्रालय/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 5/29/2023 to 6/4/2023

| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|----------------------------|----------------------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| ARUNACHAL PRADESH | 132kV Ziro-Ranganadi | NP-9704-A | AR-06 | 52353.2 | 43.6 | 52394.9 | 43.6 | 7.51 | 0.00 | 1,238 | 0 | 1,238 |
| | 132kV Khupi-Balipara | NP-9606-A | AS-55 | 24153.2 | 79.9 | 24212.7 | 79.9 | 21.42 | 0.00 | -3,534 | 0 | -3,534 |
| | 132kV Lekhi-Nirjuli | NP-9665-A | AR-10 | 1162.8 | 26894.7 | 1162.8 | 26945.4 | 0.00 | 36.50 | 0 | -6,023 | -6,023 |
| | Nirjuli-TRF 1 | NP-9661-A | AR-01 | 460.8 | 8012.1 | 460.8 | 8067 | 0.00 | 19.76 | 0 | 3,261 | 3,261 |
| | Nirjuli-TRF 2 | NP-9662-A | AR-02 | 557.5 | 6705.8 | 557.5 | 6757.5 | 0.00 | 18.61 | 0 | 3,071 | 3,071 |
| | 132kV Tenga-Balipara | NP-9696-A | AR-17 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Lekhi-Pare | NP-9607-A | PA-01 | 58704.6 | 218.6 | 58707.1 | 224.7 | 1.20 | 2.93 | -198 | 483 | 285 |
| | 132kV Chimpu-Pare | NP-9411-A | PA-05 | 2890.5 | 99975.7 | 2890.5 | 99972.9 | 0.00 | -1.34 | 0 | -222 | -222 |
| | 132kV ITANAGAR - BNC FDR 1 | NP-9935-A | AR-19 | 812 | 99468.2 | 812 | 99441.5 | 0.00 | -25.63 | 0 | 4,229 | 4,229 |
| 132kV ITANAGAR - BNC FDR 2 | NP-9939-A | AR-20 | 334.4 | 99513.1 | 334.4 | 99489.4 | 0.00 | -22.75 | 0 | 3,754 | 3,754 | |
| TOTAL | | | | | | | | | | | | 6,060 |

| | | | | | | | | | | | | | |
|-------|-------------------------------------|-----------|-------|---------|---------|---------|---------|-----------|---------|----------|--------|----------|----------------|
| ASSAM | 220kV BTPS-II - SALAKATI | NP-9435-A | AS-31 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 220kV BTPS-I - SALAKATI | NP-9434-A | AS-30 | 38414.5 | 6862.9 | 38468.4 | 6862.9 | 86.24 | 0.00 | -14,230 | 0 | -14,230 | |
| | 220kV SAMAGURI-I - MISA | NP-9583-A | AS-17 | 94108.2 | 98608.7 | 94108.8 | 98608.6 | 0.60 | -0.10 | 99 | 17 | 116 | |
| | 220kV SAMAGURI-II - MISA | NP-9713-A | AS-18 | 12778.7 | 99216.5 | 12793.4 | 99216.5 | 14.70 | 0.00 | 2,426 | 0 | 2,426 | |
| | 220kV SONABIL-BALIPARA | NP-9487-A | AS-42 | 37740.3 | 64 | 37921.7 | 64 | 290.24 | 0.00 | -47,890 | 0 | -47,890 | |
| | 220kV MARIANI - MISA | NP-9700-A | AS-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV PANCHGRAM-B'PUR(PG) | NP-6872-A | AS-07 | 6949.4 | 79846 | 6811.1 | 79846 | -99.58 | 0.00 | -16,430 | 0 | -16,430 | |
| | 132kV P'pool-JIRIBAM | NE-0039-A | MN-06 | 8007 | 19.9 | 8042.8 | 19.9 | 25.78 | 0.00 | -4,253 | 0 | -4,253 | |
| | 132kV GOHPUR-NIRJULI | NP-9688-A | AS-13 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | HAF LONG CONSUMPTION | NP-8494-A | AS-11 | 21937.1 | 3357 | 21941.5 | 3358.2 | 0.79 | 0.22 | -131 | 36 | -95 | |
| | 132kV HAILAKANDI-SILCHAR-I | NP-5301-A | AS-79 | 75909.5 | 91177.3 | 75894.8 | 91177.2 | -5.29 | -0.04 | -873 | 6 | -867 | |
| | 132kV HAILAKANDI-SILCHAR 2 | NP-9478-A | AS-80 | 80768.8 | 99934.5 | 80757.1 | 99934.5 | -4.21 | 0.00 | -695 | 0 | -695 | |
| | 132kV SONABIL-BALIPARA | NP-6150-A | AS-57 | 5597.8 | 69869.5 | 5597.8 | 69869.5 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV DEPOTA-BALIPARA | NP-6149-A | AS-56 | 58011.8 | 72679.3 | 58011.8 | 72679.3 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV SRIKONA-SILCHAR ckt I | NP-9712-A | AS-77 | 79945.5 | 99980.2 | 79885.9 | 99980.2 | -21.46 | 0.00 | -3,540 | 0 | -3,540 | |
| | 132kV SRIKONA-SILCHAR ckt2 | NP-9711-A | AS-78 | 69164.4 | 99985.5 | 69067 | 99985.5 | -35.06 | 0.00 | -5,786 | 0 | -5,786 | |
| | 132kV BOKAJAN-DIMAPUR | NP-9675-A | NG-08 | 29961 | 1532 | 29961 | 1531.7 | 0.00 | -0.29 | 0 | -48 | -48 | |
| | 400kV AZARA-BONGAIGAON | NP-9983-A | AM-01 | 92635.6 | 99796.4 | 92635.1 | 99786.4 | -3.64 | -72.73 | -600 | 12,000 | 11,400 | |
| | 400kV AZARA-SILCHAR | NP-9981-A | AS-93 | 1418 | 97603.8 | 1407.4 | 97603.8 | -77.09 | 0.00 | -12,720 | 0 | -12,720 | |
| | 132kV RANGIA-MOTANGA | NP-9669-A | AS-73 | 86717.7 | 92227.6 | 86760.8 | 92390.9 | 15.52 | 58.79 | 2,560 | -9,700 | -7,140 | |
| | 220kV Mariani-AGBPP | NP-6888-A | AS-03 | 77014.6 | 96335.3 | 76347.1 | 96335.3 | -1,068.00 | 0.00 | -176,220 | 0 | -176,220 | |
| | 132kV KARIMGANJ - BADARPUR | NP-9690-A | AM-53 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV KARIMGANJ - KUMARGHAT | NP-9937-A | AM-54 | 4860.7 | 6149 | 4861.7 | 6055.3 | 0.72 | -67.46 | 119 | 11,132 | 11,250 | |
| | 132kV Umrangshu - Khandong | NP-5290-A | AM-04 | 77785 | 98966.6 | 77940.1 | 98966.6 | 74.45 | 0.00 | 12,284 | 0 | 12,284 | |
| | 132kV Umrangshu - Haflong | NE-0019-A | AM-05 | 81700 | 99321.2 | 81522.7 | 99319.1 | -85.10 | -1.01 | -14,042 | 166 | -13,876 | |
| | 132kV PavoI - BNC Ckt I | NP-9680-A | AM-12 | 15790.4 | 72485.7 | 15790.4 | 71296.1 | 0.00 | -428.26 | 0 | 70,662 | 70,662 | |
| | 132kV PavoI - BNC Ckt II | NP-8801-A | AM-13 | 50307.1 | 67477.3 | 50307.1 | 66243.8 | 0.00 | -444.06 | 0 | 73,270 | 73,270 | |
| | Balipara end of 400 kV Bongaigaon-1 | NE-0043-A | ZZ-16 | 90101.1 | 99950.9 | 90072.1 | 99950.9 | -105.45 | 0.00 | 17,400 | 0 | 17,400 | |
| | Balipara end of 400 kV Bongaigaon-2 | NE-0047-A | ZZ-17 | 86975.4 | 2 | 86958.1 | 2 | -62.91 | 0.00 | 10,380 | 0 | 10,380 | |
| | TOTAL | | | | | | | | | | | | -94,601 |

| | | | | | | | | | | | | |
|---------|------------------------------------|-----------|-------|---------|---------|---------|---------|---------|------|--------|---|--------|
| MANIPUR | 132kV Imp(S)-Imp(PG) Ckt II | NP-9546-A | MN-23 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Imp(S)-Imp(PG) Ckt I | NP-9544-A | ZZ-01 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | JIRIBAM-TRF | NP-8501-A | MN-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV JIRIBAM (S) - Jiribam (PG) | NP-9523-A | MN-12 | 98465.5 | 99869.3 | 98470.4 | 99869.3 | 1.76 | 0.00 | -291 | 0 | -291 |
| | IMPHAL (PG) ICT I | NP-9520-A | MN-13 | 22153.8 | 384.6 | 22175.3 | 384.6 | 7.74 | 0.00 | -1,277 | 0 | -1,277 |
| | IMPHAL (PG) ICT II | NP-9522-A | MN-14 | 19657.1 | 384 | 19678.3 | 384 | 7.63 | 0.00 | -1,259 | 0 | -1,259 |
| | 132kV NINGTHOUKHONG-IMPHAL (PG) | NP-9518-A | MN-10 | 41983.2 | 99419.5 | 41912.8 | 99419.5 | -25.34 | 0.00 | 4,182 | 0 | 4,182 |
| | 132kV Imp(S)-Imp(PG) Ckt III | NP-9689-A | MN-22 | 93856.6 | 19.4 | 93842.6 | 19.4 | -10.08 | 0.00 | 1,663 | 0 | 1,663 |
| | 400kV THOUBAL-IMPHAL(PG) 1 | NP-9547-A | MN-24 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 400kV THOUBAL-IMPHAL(PG) 2 | NP-9543-A | MN-25 | 3009.5 | 0.4 | 2960 | 0.4 | -360.00 | 0.00 | 59,400 | 0 | 59,400 |
| | 132/33 50 MVA IMPHAL ICT 1 LV SIDE | NE-0048-A | ZZ-71 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132/33 50 MVA IMPHAL ICT 2 LV SIDE | NE-0018-A | ZZ-72 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Aizwal | NE-0169-A | MN-20 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Jiribam | NE-0167-A | MN-21 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | TOTAL | | | | | | | | | | | |


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक/Director
 उप-पुणे नि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 दिल्ली/Shillong


| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|--------------|--|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| MEGHALAYA | 132kV KHLRT S-PG | NP-6865-A | ME-02 | 94116.7 | 80703.5 | 94116.1 | 80700.2 | -0.43 | -2.38 | -71 | 392 | 321 |
| | 132kV KHLRT S-PG II | NP-6880-A | ME-09 | 164 | 21884.9 | 158.8 | 21905.1 | -3.74 | 14.54 | 618 | 2,400 | 3,018 |
| | 220kV BYRNIHAT-MISA | NP-9092-A | AS-70 | 89812.7 | 85965.9 | 89812.3 | 85965.9 | -0.64 | 0.00 | 106 | 0 | 106 |
| | 220kV BYRNIHAT-MISA II | NP-9091-A | AS-72 | 83595.8 | 96033.2 | 83593.3 | 96033.2 | -4.00 | 0.00 | 660 | 0 | 660 |
| | 400kV BYRNIHAT-B'GAON | NP-8370-A | ME-14 | 4880.3 | 99953.7 | 4565.8 | 99953.7 | -1,143.64 | 0.00 | -188,700 | 0 | -188,700 |
| | 400kV BYRNIHAT-SILCHAR | NP-8371-A | ME-15 | 25799.4 | 99864 | 25726.5 | 99864 | -265.09 | 0.00 | -43,740 | 0 | -43,740 |
| TOTAL | | | | | | | | | | | | -228,336 |
| MIZORAM | 132kV LAUNGMUAL-AIZWAL PG | NP-9495-A | MZ-02 | 443.6 | 6643.6 | 450.3 | 6781.5 | 2.41 | 49.64 | -398 | 8,191 | 7,793 |
| | 132kV ZUANGTUI-MELRIAT PG | NP-9563-A | MZ-14 | 70934.2 | 52462.8 | 70878.3 | 52516 | -20.12 | 19.15 | 3,320 | 3,160 | 6,481 |
| | 132kV KOLASIB-BADARPUR PG | NE-0086-A | MZ-11 | 318.4 | 99872.9 | 329.1 | 99849.7 | 3.85 | -8.35 | 636 | 1,378 | 2,014 |
| | 132kV KOLASIB-AIZAWL PG | NE-0087-A | MZ-12 | 498.6 | 25.8 | 492.1 | 29.3 | -4.68 | 2.52 | -772 | -416 | -1,188 |
| TOTAL | | | | | | | | | | | | 15,099 |
| NAGALAND | 132kV DIMAPUR S-PG I | NP-9602-A | NG-01 | 17197 | 9464 | 17197 | 9477.2 | 0.00 | 12.67 | 0 | 2,091 | 2,091 |
| | 132kV DIMAPUR S-PG II | NP-9649-A | NG-17 | 74605.2 | 4499.1 | 74605.2 | 4523.9 | 0.00 | 17.86 | 0 | 2,946 | 2,946 |
| | 132kV KOHIMA-DIMAPUR PG | NP-8472-A | NG-16 | 6292.5 | 98286.7 | 6292.5 | 98287.1 | 0.00 | 0.14 | 0 | 24 | 24 |
| | 132kV M'CHANG S-PG I | NP-9653-A | NG-20 | 44494.4 | 4864.9 | 44494.4 | 4868.2 | 0.00 | 1.19 | 0 | -196 | -196 |
| | 132kV M'CHANG S-PG II | NP-9655-A | NG-21 | 43909.1 | 4945.7 | 43909.1 | 4948.8 | 0.00 | 1.12 | 0 | -184 | -184 |
| TOTAL | | | | | | | | | | | | 4,681 |
| TRIPURA | 132kV PK BARI-KUMARGHAT | NP-6860-A | TR-04 | 97414.5 | 84658.6 | 97414.5 | 84658.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI-SILCHAR I | NP-9709-A | TR-15 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI-SILCHAR II | NP-9710-A | TR-16 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Agartala-AGTPP Ckt I | NP-6850-A | TR-01 | 8515 | 6224.9 | 8515 | 6224.9 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Agartala-AGTPP Ckt II | NP-6851-A | TR-02 | 48157.4 | 93754.6 | 48157.4 | 93754.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV SM Nagar-Palatana | NP-8471-A | TR-13 | 68831.5 | 72313.3 | 68831.5 | 72313.3 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE) | NP-9893-A | TR-28 | 7321.4 | 99970.6 | 7321.4 | 99970.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE) | NP-9890-A | TR-29 | 14641.6 | 26.3 | 14641.6 | 26.3 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI (TSECL) - PK BARI (STERLITE) | NP-9931-A | TR-24 | 10332.3 | 99994.9 | 10334.6 | 99994.9 | 2.21 | 0.00 | -364 | 0 | -364 |
| | 132kV AMBASSA (TSECL) - PK BARI (STERLITE) | NP-9930-A | TR-25 | 4759.2 | 99999.7 | 4760.3 | 99999.7 | 1.06 | 0.00 | -174 | 0 | -174 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT I | NP-9933-A | TR-21 | 1468.8 | 99976.9 | 1468.8 | 99976.9 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT II | NP-9932-A | TR-22 | 1355.1 | 99997.2 | 1355.1 | 99997.2 | 0.00 | 0.00 | 0 | 0 | 0 |
| TOTAL | | | | | | | | | | | | -539 |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/kVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S.M. Almol) S.M. Almol
 Director
 Director General/NERPC
 Ministry of Power
 Govt. of India
 Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 5/29/2023 to 6/4/2023


| Beneficiary | Line Name | To Beneficiary | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | Effective Net Reactive Charge |
|-------------------------|---------------------|----------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|-------------------------------|
| | | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | |
| ASSAM | KAHELIPARA-UMTRU II | MEGHALAYA | NE-0089-A | AS-02 | 98322.3 | 99834.6 | 98318.2 | 99801.7 | -1.968 | -15.792 | -325 | 2,606 | 0 |
| | | | NE-0016-A | ME-04 | 0.6 | 0 | 0.6 | 0 | 0 | 0 | 0 | 0 | |
| | KAHELIPARA-UMTRU I | MEGHALAYA | NE-0088-A | AS-01 | 97686.2 | 99724.4 | 97681.2 | 99671.8 | -2.4 | -25.248 | -396 | 4,166 | 0 |
| | | | NP-8474-A | ME-03 | 99244 | 99984.8 | 99244 | 99984.8 | 0 | 0 | 0 | 0 | |
| | S'SUJAI-UMTRU I | MEGHALAYA | NP-9921-A | AS-09 | 99982.6 | 0.3 | 99982.6 | 0.3 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8473-A | ME-07 | 92670.2 | 99820.3 | 92642.6 | 99820.2 | -13.248 | -0.048 | -2,186 | 8 | |
| | S'SUJAI-UMTRU II | MEGHALAYA | NP-9922-A | AS-50 | 99987.8 | 0 | 99987.8 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8491-A | ME-05 | 93569.9 | 99794.7 | 93542.5 | 99794.7 | -13.152 | 0 | -2,170 | 0 | |
| | PANCHGRAM-LUMSHONG | MEGHALAYA | NP-7595-A | AS-06 | 87836.2 | 1085.1 | 87836.2 | 1085.1 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8384-A | ME-01 | 94399.5 | 60796.2 | 94398 | 60788.2 | -0.72 | -3.84 | -119 | 634 | |
| | AGIA-Mendhipathar | MEGHALAYA | NP-9455-A | AS-86 | 76546.5 | 6650.3 | 76542.5 | 6701.3 | -1.92 | 24.48 | -317 | -4,039 | -4,356 |
| | | | NP-9071-A | ME-16 | 89356.8 | 21856.9 | 89361.6 | 21668.1 | 2.304 | -90.624 | 380 | 14,953 | |
| 132 KV AGIA-NANGALBIBRA | MEGHALAYA | NP-9920-A | AM-58 | 69183.8 | 306.7 | 69183.3 | 213.8 | -0.18 | -33.444 | -30 | 5,518 | -30 | |
| | | NP-9945-A | ME-17 | 99904.4 | 92122.5 | 99944.3 | 91706.3 | 14.364 | -149.832 | 2,370 | 24,722 | | |
| TOTAL | | | | | | | | | | | | | -4,386 |
| ASSAM | D'CHERRA - D'NAGAR | TRIPURA | NP-9904-A | AS-08 | 21225.2 | 99636.9 | 21226.7 | 99666.8 | 0.72 | 14.352 | 119 | -2,368 | -2,368 |
| | | | NP-6892-B | TR-06 | 76269 | 49486.3 | 76269 | 48928.4 | 0 | -267.792 | 0 | 44,186 | |
| TOTAL | | | | | | | | | | | | | -2,368 |
| MANIPUR | 132KV KARONG-KOHIMA | NAGALAND | NP-9667-A | MN-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-9947-A | NG-02 | 1737.7 | 99839.7 | 1737.6 | 99852.2 | -0.048 | 6 | -8 | -990 | |
| TOTAL | | | | | | | | | | | | | 0 |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/kVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम. आइमोल/S.M. Aimol)
 निदेशक/Director
 उप क्षेत्रीय/Min. of Power
 विद्युत विभाग/Govt. of India
 शिलांग/Shillong


Reactive Energy (VArH) Charge Statement
for the period 6/5/2023 to 6/11/2023

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

| BENEFICIARY | AMOUNT PAYABLE TO POOL(Rs.) | AMOUNT RECEIVABLE FROM POOL (Rs.) |
|--------------------|------------------------------------|--|
| ARUNACHAL PRADESH | 0 | 7,215 |
| ASSAM | 0 | 237,015 |
| MANIPUR | 18,265 | 0 |
| MEGHALAYA | 0 | 298,899 |
| MIZORAM | 14,589 | 0 |
| NAGALAND | 4,966 | 0 |
| TRIPURA | 0 | 42,392 |

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

| RECEIVABLE BENEFICIARY | FROM BENEFICIARY | AMOUNT RECEIVABLE (Rs.) |
|-------------------------------|-------------------------|--------------------------------|
| ASSAM | MEGHALAYA | 15,763 |
| ASSAM | TRIPURA | 356 |
| MANIPUR | NAGALAND | 0 |
| MEGHALAYA | ASSAM | 0 |
| NAGALAND | MANIPUR | 0 |
| TRIPURA | ASSAM | 0 |



(एम.एस. आइमोल/S.M.Aimol)
निदेशक/Director
उत्प. क्षेत्र/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 6/5/2023 to 6/11/2023

| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|----------------------------|----------------------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| ARUNACHAL PRADESH | 132kV Ziro-Ranganadi | NP-9704-A | AR-06 | 52415.1 | 43.6 | 52455.4 | 43.7 | 7.25 | 0.02 | 1,197 | -3 | 1,194 |
| | 132kV Khupi-Balipara | NP-9606-A | AS-55 | 24222.7 | 79.9 | 24341.7 | 79.9 | 42.84 | 0.00 | -7,069 | 0 | -7,069 |
| | 132kV Lekhi-Nirjuli | NP-9665-A | AR-10 | 1162.8 | 26945.9 | 1162.8 | 27032.5 | 0.00 | 62.35 | 0 | -10,288 | -10,288 |
| | Nirjuli-TRF 1 | NP-9661-A | AR-01 | 460.8 | 8067.8 | 460.8 | 8132.9 | 0.00 | 23.44 | 0 | 3,867 | 3,867 |
| | Nirjuli-TRF 2 | NP-9662-A | AR-02 | 557.6 | 6758.2 | 557.6 | 6821 | 0.00 | 22.61 | 0 | 3,730 | 3,730 |
| | 132kV Tenga-Balipara | NP-9696-A | AR-17 | 44372.3 | 6.4 | 44369.4 | 6.4 | -2.09 | 0.00 | -345 | 0 | -345 |
| | 132kV Lekhi-Pare | NP-9607-A | PA-01 | 58725 | 224.7 | 58725.3 | 224.8 | 0.14 | 0.05 | -24 | 8 | -16 |
| | 132kV Chimpu-Pare | NP-9411-A | PA-05 | 2892.2 | 99972.9 | 2892.2 | 99972.9 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV ITANAGAR - BNC FDR 1 | NP-9935-A | AR-19 | 813 | 99441.5 | 813 | 99436.5 | 0.00 | -4.80 | 0 | 792 | 792 |
| 132kV ITANAGAR - BNC FDR 2 | NP-9939-A | AR-20 | 334.8 | 99489.4 | 334.8 | 99483.6 | 0.00 | -5.57 | 0 | 919 | 919 | |
| TOTAL | | | | | | | | | | | | -7,215 |

| | | | | | | | | | | | | | |
|-------|-------------------------------------|-----------|-------|---------|---------|---------|---------|-----------|---------|----------|---------|----------|-----------------|
| ASSAM | 220kV BTPS-II - SALAKATI | NE-0064-A | AS-31 | 31 | 0.8 | 292 | 0.8 | 417.60 | 0.00 | -68,904 | 0 | -68,904 | |
| | 220kV BTPS-I - SALAKATI | NP-9434-A | AS-30 | 38486.3 | 6862.9 | 38808.1 | 6862.9 | 514.88 | 0.00 | -84,955 | 0 | -84,955 | |
| | 220kV SAMAGURI-I - MISA | NP-9583-A | AS-17 | 94109.8 | 98608.6 | 94114.1 | 98606 | 4.30 | -2.60 | 710 | 429 | 1,139 | |
| | 220kV SAMAGURI-II - MISA | NP-9713-A | AS-18 | 12806.5 | 99216.5 | 12812.8 | 99216.1 | 6.30 | -0.40 | 1,040 | 66 | 1,106 | |
| | 220kV SONABIL-BALIPARA | NP-9487-A | AS-42 | 37967.5 | 64 | 38219.6 | 64 | 403.36 | 0.00 | -66,554 | 0 | -66,554 | |
| | 220kV MARIANI - MISA | NP-9700-A | AS-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV PANCHGRAM-B'PUR(PG) | NP-6872-A | AS-07 | 6802.8 | 79846 | 6704.9 | 79845.9 | -70.49 | -0.07 | -11,631 | 12 | -11,619 | |
| | 132kV P'pool-JIRIBAM | NE-0039-A | MN-06 | 8042.8 | 19.9 | 8054.1 | 19.9 | 8.14 | 0.00 | -1,342 | 0 | -1,342 | |
| | 132kV GOHPUR-NIRJULI | NP-9688-A | AS-13 | 99501.8 | 82255 | 99501.8 | 82255 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | HAF LONG CONSUMPTION | NP-8494-A | AS-11 | 2194.18 | 3358.7 | 21949.8 | 3359.2 | 1.44 | 0.09 | -238 | 15 | -223 | |
| | 132kV HAILAKANDI-SILCHAR-I | NP-5301-A | AS-79 | 75894.8 | 91177.2 | 75869.7 | 91177.1 | -9.04 | -0.04 | -1,491 | 6 | -1,485 | |
| | 132kV HAILAKANDI-SILCHAR 2 | NP-9478-A | AS-80 | 80757.1 | 99934.5 | 80733.2 | 99934.5 | -8.60 | 0.00 | -1,420 | 0 | -1,420 | |
| | 132 KV SONABIL-BALIPARA | NP-6150-A | AS-57 | 5597.8 | 69869.5 | 5597.8 | 69869.5 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV DEPOTA-BALIPARA | NP-6149-A | AS-56 | 58011.8 | 72679.3 | 58011.8 | 72679.3 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV SRIKONA-SILCHAR ckt I | NP-9712-A | AS-77 | 79885.1 | 99980.2 | 79788.2 | 99980.2 | -34.88 | 0.00 | -5,756 | 0 | -5,756 | |
| | 132kV SRIKONA-SILCHAR ckt2 | NP-9711-A | AS-78 | 69060.5 | 99985.5 | 68925.4 | 99985.5 | -48.64 | 0.00 | -8,025 | 0 | -8,025 | |
| | 132kV BOKAJAN-DIMAPUR | NP-9675-A | NG-08 | 29961 | 1531.7 | 29961 | 1532.8 | 0.00 | 1.06 | 0 | 174 | 174 | |
| | 400kV AZARA-BONGAIGAON | NP-9983-A | AM-01 | 92626.3 | 99786.4 | 92626 | 99786.4 | -2.18 | 0.00 | -360 | 0 | -360 | |
| | 400kV AZARA-SILCHAR | NP-9981-A | AS-93 | 1399.1 | 97603.8 | 1399.1 | 97603.7 | 0.00 | -0.73 | 0 | 120 | 120 | |
| | 132kV RANGIA-MOTANGA | NP-9669-A | AS-73 | 86783.1 | 92391.5 | 87072.7 | 92662.6 | 104.26 | 97.60 | 17,202 | -16,103 | 1,099 | |
| | 220kV Mariani-AGBPP | NP-6888-A | AS-03 | 76249.3 | 96335.3 | 75475.8 | 96335.3 | -1,237.60 | 0.00 | -204,204 | 0 | -204,204 | |
| | 132kV KARIMGANJ - BADARPUR | NP-9690-A | AM-53 | 93586.9 | 98837.8 | 93584.9 | 98821.4 | -1.44 | -11.81 | -238 | 1,948 | 1,711 | |
| | 132kV KARIMGANJ - KUMARGHAT | NP-9937-A | AM-54 | 4861.7 | 6050.9 | 4861.7 | 5836.9 | 0.00 | -154.08 | 0 | 25,423 | 25,423 | |
| | 132kV Umrangshu - Khandong | NP-5290-A | AM-04 | 77964.8 | 98968 | 78113 | 98968.5 | 71.14 | 0.24 | 11,737 | -40 | 11,698 | |
| | 132kV Umrangshu - Haflong | NE-0019-A | AM-05 | 81497.9 | 99317.3 | 81309.5 | 99316.5 | -90.43 | -0.38 | -14,921 | 63 | -14,858 | |
| | 132kV PavoI - BNC Ckt I | NP-9680-A | AM-12 | 15790.4 | 71149.9 | 15790.4 | 69818.6 | 0.00 | -479.27 | 0 | 79,079 | 79,079 | |
| | 132kV PavoI - BNC Ckt II | NP-8801-A | AM-13 | 50307.1 | 66093.5 | 50307.1 | 64709.3 | 0.00 | -498.31 | 0 | 82,221 | 82,221 | |
| | Balipara end of 400 kV Bongaigaon-1 | NE-0043-A | ZZ-16 | 90055.3 | 99950.9 | 90035.6 | 99950.9 | -71.64 | 0.00 | 11,820 | 0 | 11,820 | |
| | Balipara end of 400 kV Bongaigaon-2 | NE-0047-A | ZZ-17 | 86948.3 | 2 | 86919.8 | 2 | -103.64 | 0.00 | 17,100 | 0 | 17,100 | |
| | TOTAL | | | | | | | | | | | | -237,015 |

| | | | | | | | | | | | | |
|--------------|------------------------------------|-----------|-------|---------|---------|---------|---------|---------|------|--------|---|---------------|
| MANIPUR | 132kV Imp(S)-Imp(PG) Ckt II | NP-9546-A | MN-23 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Imp(S)-Imp(PG) Ckt I | NP-9544-A | ZZ-01 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | JIRIBAM-TRF | NP-8501-A | MN-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV JIRIBAM (S) - Jiribam (PG) | NP-9523-A | MN-12 | 98470.4 | 99869.3 | 98471.5 | 99869.3 | 0.40 | 0.00 | -65 | 0 | -65 |
| | IMPHAL (PG) ICT I | NP-9520-A | MN-13 | 22175.3 | 384.6 | 22176.2 | 384.6 | 0.32 | 0.00 | -53 | 0 | -53 |
| | IMPHAL (PG) ICT II | NP-9522-A | MN-14 | 19678.3 | 384 | 19679.1 | 384.1 | 0.29 | 0.04 | -48 | 6 | -42 |
| | 132kV NINGTHOUKHONG-IMPHAL (PG) | NP-9518-A | MN-10 | 41912.8 | 99419.5 | 41912.5 | 99419.5 | -0.11 | 0.00 | 18 | 0 | 18 |
| | 132kV Imp(S)-Imp(PG) Ckt III | NP-9689-A | MN-22 | 93842.6 | 19.4 | 93842.2 | 19.4 | -0.29 | 0.00 | 48 | 0 | 48 |
| | 400kV THOUBAL-IMPHAL(PG) 1 | NP-9547-A | MN-24 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 400kV THOUBAL-IMPHAL(PG) 2 | NP-9543-A | MN-25 | 2960 | 0.4 | 2944.7 | 0.4 | -111.27 | 0.00 | 18,360 | 0 | 18,360 |
| | 132/33 50 MVA IMPHAL ICT 1 LV SIDE | NE-0048-A | ZZ-71 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132/33 50 MVA IMPHAL ICT 2 LV SIDE | NE-0018-A | ZZ-72 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Aizwal | NE-0169-A | MN-20 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Jiribam | NE-0167-A | MN-21 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| TOTAL | | | | | | | | | | | | 18,265 |


 (एस.एम. अलमोल/S.M. Almol)
 निदेशक/Director
 उ.पु.के.पि.स./NERPC
 कियुक्त मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong


| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|--------------|--|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| MEGHALAYA | 132kV KHLRT S-PG | NP-6865-A | ME-02 | 94117.4 | 80699.4 | 94126.8 | 80696.4 | 6.77 | -2.16 | 1,117 | 356 | 1,473 |
| | 132kV KHLRT S-PG II | NP-6880-A | ME-09 | 158.6 | 21908.5 | 151.9 | 21925.8 | -4.82 | 12.46 | 796 | 2,055 | 2,851 |
| | 220kV BYRNIHAT-MISA | NP-9092-A | AS-70 | 89812.3 | 85965.9 | 89799.1 | 85965.9 | -21.12 | 0.00 | 3,485 | 0 | 3,485 |
| | 220kV BYRNIHAT-MISA II | NP-9091-A | AS-72 | 83593.3 | 96033.2 | 83567.8 | 96033.2 | -40.80 | 0.00 | 6,732 | 0 | 6,732 |
| | 400kV BYRNIHAT-B'GAON | NP-8370-A | ME-14 | 4456.7 | 99953.7 | 4104.8 | 99953.7 | -1,279.64 | 0.00 | -211,140 | 0 | -211,140 |
| | 400kV BYRNIHAT-SILCHAR | NP-8371-A | ME-15 | 25729.2 | 99864 | 25558.7 | 99864 | -620.00 | 0.00 | -102,300 | 0 | -102,300 |
| TOTAL | | | | | | | | | | | | -298,899 |
| MIZORAM | 132kV LAUNGMUAL-AIZWAL PG | NP-9495-A | MZ-02 | 450.3 | 6797 | 450.5 | 6980.3 | 0.07 | 65.99 | -12 | 10,888 | 10,876 |
| | 132kV ZUANGTUI-MELRIAT PG | NP-9563-A | MZ-14 | 70878.3 | 52505.3 | 70876.1 | 52526.1 | -0.79 | 7.49 | 131 | 1,236 | 1,366 |
| | 132kV KOLASIB-BADARPUR PG | NE-0086-A | MZ-11 | 329.1 | 99849.7 | 329.7 | 99805.6 | 0.22 | -15.88 | 36 | 2,620 | 2,655 |
| | 132kV KOLASIB-AIZAWL PG | NE-0087-A | MZ-12 | 492.1 | 29.3 | 493.8 | 33.6 | 1.22 | 3.10 | 202 | -511 | -309 |
| TOTAL | | | | | | | | | | | | 14,589 |
| NAGALAND | 132kV DIMAPUR S-PG I | NP-9602-A | NG-01 | 17197 | 9477.5 | 17197 | 9491.9 | 0.00 | 13.82 | 0 | 2,281 | 2,281 |
| | 132kV DIMAPUR S-PG II | NP-9649-A | NG-17 | 74605.2 | 4524.4 | 74605.2 | 4553.7 | 0.00 | 21.10 | 0 | 3,481 | 3,481 |
| | 132kV KOHIMA-DIMAPUR PG | NP-8472-A | NG-16 | 6292.5 | 98287.1 | 6292.5 | 98285.5 | 0.00 | -0.58 | 0 | -95 | -95 |
| | 132kV M'CHANG S-PG I | NP-9653-A | NG-20 | 44494.4 | 4868.2 | 44494.4 | 4873.7 | 0.00 | 1.98 | 0 | -327 | -327 |
| | 132kV M'CHANG S-PG II | NP-9655-A | NG-21 | 43909.1 | 4948.8 | 43909.1 | 4955.1 | 0.00 | 2.27 | 0 | -374 | -374 |
| TOTAL | | | | | | | | | | | | 4,966 |
| TRIPURA | 132kV PK BARI-KUMARGHAT | NP-6860-A | TR-04 | 97414.5 | 84658.6 | 97414 | 84658.6 | -0.36 | 0.00 | 59 | 0 | 59 |
| | 132kV PK BARI-SILCHAR I | NP-9709-A | TR-15 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI-SILCHAR II | NP-9710-A | TR-16 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Agartala-AGTPP Ckt I | NP-6850-A | TR-01 | 8515 | 6224.9 | 8511.7 | 6224.9 | -3.17 | 0.00 | -523 | 0 | -523 |
| | 132kV Agartala-AGTPP Ckt II | NP-6851-A | TR-02 | 48157.4 | 93754.6 | 48156.6 | 93754.6 | -0.77 | 0.00 | -127 | 0 | -127 |
| | 132kV SM Nagar-Palatana | NP-8471-A | TR-13 | 68831.5 | 72313.3 | 68831.1 | 72313.3 | -0.48 | 0.00 | -79 | 0 | -79 |
| | 132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE) | NP-9893-A | TR-28 | 7321.4 | 99970.6 | 7360.5 | 99970.6 | 37.54 | 0.00 | -6,193 | 0 | -6,193 |
| | 132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE) | NP-9890-A | TR-29 | 14641.6 | 26.3 | 14710.8 | 26.3 | 66.43 | 0.00 | -10,961 | 0 | -10,961 |
| | 132kV PK BARI (TSECL) - PK BARI (STERLITE) | NP-9931-A | TR-24 | 10334.6 | 99994.9 | 10452.2 | 99994.9 | 112.90 | 0.00 | -18,628 | 0 | -18,628 |
| | 132kV AMBASSA (TSECL) - PK BARI (STERLITE) | NP-9930-A | TR-25 | 4760.3 | 99999.7 | 4799.6 | 99999.7 | 37.73 | 0.00 | -6,225 | 0 | -6,225 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT I | NP-9933-A | TR-21 | 1468.8 | 99976.9 | 1468.8 | 99976.9 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT II | NP-9932-A | TR-22 | 1355.1 | 99997.2 | 1356.9 | 99997.2 | 1.73 | 0.00 | 285 | 0 | 285 |
| | TOTAL | | | | | | | | | | | |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/kVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGG, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम. आइमल / S.M. Aimal)
 निदेशक/Director
 उ.पु.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 6/5/2023 to 6/11/2023


| Beneficiary | Line Name | To Beneficiary | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | Effective Net Reactive Charge |
|--------------|-------------------------|----------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|-------------------------------|
| | | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | |
| ASSAM | KAHELIPARA-UMTRU II | MEGHALAYA | NE-0089-A | AS-02 | 98314.9 | 99799.2 | 98303.4 | 99782.6 | -5.52 | -7.968 | -911 | 1,315 | 0 |
| | | | NE-0016-A | ME-04 | 0.6 | 0 | 0.6 | 0 | 0 | 0 | 0 | 0 | |
| | KAHELIPARA-UMTRU I | MEGHALAYA | NE-0088-A | AS-01 | 97676.8 | 99667.5 | 97662.3 | 99641 | -6.96 | -12.72 | -1,148 | 2,099 | 0 |
| | | | NP-8474-A | ME-03 | 99244 | 99984.8 | 99244 | 99984.8 | 0 | 0 | 0 | 0 | |
| | S'SUJAI-UMTRU I | MEGHALAYA | NP-9921-A | AS-09 | 99982.6 | 0.3 | 99982.6 | 0.3 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8473-A | ME-07 | 92638.4 | 99820.2 | 92622.2 | 99820.2 | -7.776 | 0 | -1,283 | 0 | |
| | S'SUJAI-UMTRU II | MEGHALAYA | NP-9922-A | AS-50 | 99987.8 | 0 | 99987.8 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8491-A | ME-05 | 93538.4 | 99794.7 | 93522.4 | 99794.7 | -7.68 | 0 | -1,267 | 0 | |
| | PANCHGRAM-LUMSHONG | MEGHALAYA | NP-7595-A | AS-06 | 87836.2 | 1085.1 | 87836.2 | 1085.1 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8384-A | ME-01 | 94398 | 60788 | 94398.7 | 60784.9 | 0.336 | -1.488 | 55 | 246 | |
| | AGIA-Mendhipathar | MEGHALAYA | NP-9455-A | AS-86 | 76505.1 | 6702.1 | 76339.1 | 6669 | -79.68 | -15.888 | -13,147 | 2,622 | -8,451 |
| | | | NP-9071-A | ME-16 | 89388.6 | 21653.2 | 89495.3 | 21625.4 | 51.216 | -13.344 | 8,451 | 2,202 | |
| | 132 KV AGIA-NANGALBIBRA | MEGHALAYA | NP-9920-A | AM-58 | 69137 | 189.9 | 68938.5 | 86.1 | -71.46 | -37.368 | -11,791 | 6,166 | -7,312 |
| | | | NP-9945-A | ME-17 | 99959.8 | 91669.7 | 82.9 | 91513.8 | 44.316 | -56.124 | 7,312 | 9,260 | |
| TOTAL | | | | | | | | | | | | | -15,763 |
| ASSAM | D'CHERRA - D'NAGAR | TRIPURA | NP-9904-A | AS-08 | 21226.7 | 99666.8 | 21235.9 | 99662 | 4.416 | -2.304 | 729 | 380 | -356 |
| | | | NP-6892-B | TR-06 | 76269 | 48784.8 | 76269 | 48789.3 | 0 | 2.16 | 0 | -356 | |
| TOTAL | | | | | | | | | | | | | -356 |
| MANIPUR | 132KV KARONG-KOHIMA | NAGALAND | NP-9667-A | MN-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-9947-A | NG-02 | 1737.6 | 99852.2 | 1737.6 | 99852.2 | 0 | 0 | 0 | 0 | |
| TOTAL | | | | | | | | | | | | | 0 |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S.M. Anmol)
 निदेशक/Director
 उ.पु.वि.वि.प./NEERC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong


Reactive Energy (VArH) Charge Statement
for the period 6/12/2023 to 6/18/2023

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

| BENEFICIARY | AMOUNT PAYABLE TO POOL(Rs.) | AMOUNT RECEIVABLE FROM POOL (Rs.) |
|--------------------|------------------------------------|--|
| ARUNACHAL PRADESH | 0 | 3,368 |
| ASSAM | 0 | 229,514 |
| MANIPUR | 3,156 | 0 |
| MEGHALAYA | 0 | 593,859 |
| MIZORAM | 8,684 | 0 |
| NAGALAND | 4 | 0 |
| TRIPURA | 67 | 0 |

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

| RECEIVABLE BENEFICIARY | FROM BENEFICIARY | AMOUNT RECEIVABLE (Rs.) |
|-------------------------------|-------------------------|--------------------------------|
| ASSAM | MEGHALAYA | 31,947 |
| ASSAM | TRIPURA | 8 |
| MANIPUR | NAGALAND | 0 |
| MEGHALAYA | ASSAM | 0 |
| NAGALAND | MANIPUR | 0 |
| TRIPURA | ASSAM | 0 |



(एस.एम. आइमोल/S.M.Aimol)
निदेशक/Director
उ.पु.वे.वि.स/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 6/12/2023 to 6/18/2023

| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|----------------------------|----------------------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| ARUNACHAL PRADESH | 132kV Ziro-Ranganadi | NP-9704-A | AR-06 | 52455.4 | 43.7 | 52455.4 | 43.7 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Khupi-Balipara | NP-9606-A | AS-55 | 24295.2 | 79.9 | 24221.1 | 79.9 | -26.68 | 0.00 | 4,402 | 0 | 4,402 |
| | 132kV Lekhi-Nirjuli | NP-9665-A | AR-10 | 1162.8 | 27032.5 | 1162.8 | 27032.5 | 0.00 | 0.00 | 0 | 0 | 0 |
| | Nirjuli-TRF 1 | NP-9661-A | AR-01 | 460.8 | 8132.9 | 460.8 | 8137.4 | 0.00 | 1.62 | 0 | 267 | 267 |
| | Nirjuli-TRF 2 | NP-9662-A | AR-02 | 557.6 | 6821 | 557.6 | 6824.7 | 0.00 | 1.33 | 0 | 220 | 220 |
| | 132kV Tenga-Balipara | NP-9696-A | AR-17 | 44334.9 | 6.4 | 44265.4 | 6.4 | -50.04 | 0.00 | -8,257 | 0 | -8,257 |
| | 132kV Lekhi-Pare | NP-9607-A | PA-01 | 58725.3 | 224.8 | 58725.3 | 224.8 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Chimpu-Pare | NP-9411-A | PA-05 | 2892.2 | 99972.9 | 2892.2 | 99972.9 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV ITANAGAR - BNC FDR 1 | NP-9935-A | AR-19 | 813 | 99436.5 | 813 | 99436.5 | 0.00 | 0.00 | 0 | 0 | 0 |
| 132kV ITANAGAR - BNC FDR 2 | NP-9939-A | AR-20 | 334.8 | 99483.6 | 334.8 | 99483.6 | 0.00 | 0.00 | 0 | 0 | 0 | |
| TOTAL | | | | | | | | | | | | -3,368 |

| | | | | | | | | | | | | | |
|-------|-------------------------------------|-----------|-------|---------|---------|---------|---------|-----------|--------|----------|--------|----------|-----------------|
| ASSAM | 220kV BTPS-II - SALAKATI | NE-0064-A | AS-31 | 303.2 | 0.8 | 379.3 | 0.8 | 121.76 | 0.00 | -20,090 | 0 | -20,090 | |
| | 220kV BTPS-I - SALAKATI | NP-9434-A | AS-30 | 38843.7 | 6862.9 | 38987.3 | 6862.9 | 229.76 | 0.00 | -37,910 | 0 | -37,910 | |
| | 220kV SAMAGURI-I - MISA | NP-9583-A | AS-17 | 94246.4 | 98606 | 94259.2 | 98606 | 12.80 | 0.00 | 2,112 | 0 | 2,112 | |
| | 220kV SAMAGURI-II - MISA | NP-9713-A | AS-18 | 12998.7 | 99216.1 | 13055.1 | 99216.1 | 56.40 | 0.00 | 9,306 | 0 | 9,306 | |
| | 220kV SONABIL-BALIPARA | NP-9487-A | AS-42 | 38219.6 | 64 | 38205.2 | 64 | -23.04 | 0.00 | 3,802 | 0 | 3,802 | |
| | 220kV MARIANI - MISA | NP-9700-A | AS-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV PANCHGRAM-B'PUR(PG) | NP-6872-A | AS-07 | 6662 | 79845.9 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV P'pool-JIRIBAM | NE-0039-A | MN-06 | 8054.4 | 19.9 | 8128 | 19.9 | 52.99 | 0.00 | -8,744 | 0 | -8,744 | |
| | 132kV GOHPUR-NIRJULI | NP-9688-A | AS-13 | 99501.8 | 82255 | 99501.8 | 82255 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | HAF LONG CONSUMPTION | NP-8494-A | AS-11 | 21952.8 | 3359.2 | 21963.2 | 3359.2 | 1.87 | 0.00 | -309 | 0 | -309 | |
| | 132kV HAILAKANDI-SILCHAR-I | NP-5301-A | AS-79 | 75865.5 | 91177.1 | 75840 | 91177.1 | -9.18 | 0.00 | -1,515 | 0 | -1,515 | |
| | 132kV HAILAKANDI-SILCHAR 2 | NP-9478-A | AS-80 | 80729.6 | 99934.5 | 80705.1 | 99934.5 | -8.82 | 0.00 | -1,455 | 0 | -1,455 | |
| | 132kV SONABIL-BALIPARA | NP-6150-A | AS-57 | 5597.8 | 69869.5 | 5597.8 | 69869.5 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV DEPOTA-BALIPARA | NP-6149-A | AS-56 | 58011.8 | 72679.3 | 58011.8 | 72679.3 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV SRIKONA-SILCHAR ckt I | NP-9712-A | AS-77 | 79783.5 | 99980.1 | 79769.7 | 99980.1 | -4.97 | 0.00 | -820 | 0 | -820 | |
| | 132kV SRIKONA-SILCHAR ckt2 | NP-9711-A | AS-78 | 68903.8 | 99985.5 | 68869.4 | 99985.5 | -12.38 | 0.00 | -2,043 | 0 | -2,043 | |
| | 132kV BOKAJAN-DIMAPUR | NP-9675-A | NG-08 | 29962.8 | 1532.8 | 29962.8 | 1532.8 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 400kV AZARA-BONGAIGAON | NP-9983-A | AM-01 | 92625.7 | 99786.4 | 92625.3 | 99786.4 | -2.91 | 0.00 | -480 | 0 | -480 | |
| | 400kV AZARA-SILCHAR | NP-9981-A | AS-93 | 1399 | 97603.7 | 1398.3 | 97603.7 | -5.09 | 0.00 | -840 | 0 | -840 | |
| | 132kV RANGIA-MOTANGA | NP-9669-A | AS-73 | 87073.7 | 92659.4 | 87188.2 | 92716.3 | 41.22 | 20.48 | 6,801 | -3,380 | 3,421 | |
| | 220kV Mariani-AGBPP | NP-6888-A | AS-03 | 75341.4 | 96335.3 | 74584.8 | 96335.2 | -1,210.56 | -0.16 | -199,742 | 26 | -199,716 | |
| | 132kV KARIMGANJ - BADARPUR | NP-9690-A | AM-53 | 93584.9 | 98821.4 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV KARIMGANJ - KUMARGHAT | NP-9937-A | AM-54 | 4861.7 | 5832.4 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV Umrangshu - Khandong | NP-5290-A | AM-04 | 78152 | 98968.5 | 78698.1 | 98968.5 | 262.13 | 0.00 | 43,251 | 0 | 43,251 | |
| | 132kV Umrangshu - Haflong | NE-0019-A | AM-05 | 81266.6 | 99316.5 | 80743.3 | 99316.5 | -251.18 | 0.00 | -41,445 | 0 | -41,445 | |
| | 132kV PavoI - BNC Ckt I | NP-9680-A | AM-12 | 15790.4 | 69813.9 | 15790.4 | 69624.6 | 0.00 | -68.15 | 0 | 11,244 | 11,244 | |
| | 132kV PavoI - BNC Ckt II | NP-8801-A | AM-13 | 50307.1 | 64702.8 | 50307.1 | 64488.7 | 0.00 | -77.08 | 0 | 12,718 | 12,718 | |
| | Balipara end of 400 kV Bongaigaon-1 | NE-0043-A | ZZ-16 | 90035.6 | 99950.9 | 90035.6 | 99950.9 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | Balipara end of 400 kV Bongaigaon-2 | NE-0047-A | ZZ-17 | 86907.4 | 2 | 86907.4 | 2 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | TOTAL | | | | | | | | | | | | -229,514 |

| | | | | | | | | | | | | |
|---------|------------------------------------|-----------|-------|---------|---------|---------|---------|--------|------|-------|---|-------|
| MANIPUR | 132kV Imp(S)-Imp(PG) Ckt II | NP-9546-A | MN-23 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Imp(S)-Imp(PG) Ckt I | NP-9544-A | ZZ-01 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | JIRIBAM-TRF | NP-8501-A | MN-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV JIRIBAM (S) - Jiribam (PG) | NP-9523-A | MN-12 | 98471.5 | 99869.3 | 98470.9 | 99869.3 | -0.22 | 0.00 | 36 | 0 | 36 |
| | IMPHAL (PG) ICT I | NP-9520-A | MN-13 | 22176.2 | 384.6 | 22176.2 | 384.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | IMPHAL (PG) ICT II | NP-9522-A | MN-14 | 19679.1 | 384.1 | 19679.1 | 384.1 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV NINGTHOUKHONG-IMPHAL (PG) | NP-9518-A | MN-10 | 41912.5 | 99419.5 | 41912.5 | 99419.5 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Imp(S)-Imp(PG) Ckt III | NP-9689-A | MN-22 | 93842.2 | 19.4 | 93842.2 | 19.4 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 400kV THOUBAL-IMPHAL(PG) 1 | NP-9547-A | MN-24 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 400kV THOUBAL-IMPHAL(PG) 2 | NP-9543-A | MN-25 | 2944.7 | 0.4 | 2942.1 | 0.4 | -18.91 | 0.00 | 3,120 | 0 | 3,120 |
| | 132/33 50 MVA IMPHAL ICT 1 LV SIDE | NE-0048-A | ZZ-71 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132/33 50 MVA IMPHAL ICT 2 LV SIDE | NE-0018-A | ZZ-72 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Aizwal | NE-0169-A | MN-20 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Jiribam | NE-0167-A | MN-21 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | TOTAL | | | | | | | | | | | |


 (एस.एम. आइमल / S.M. Aimal)
 निदेशक/Director
 उप-क्षेत्रीय/NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिल्लॉंग/Shillong

| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|--------------|------------------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| MEGHALAYA | 132kV KHLRT S-PG | NP-6865-A | ME-02 | 94117 | 80696.4 | 94031.4 | 80696.4 | -61.63 | 0.00 | -10,169 | 0 | -10,169 |
| | 132kV KHLRT S-PG II | NP-6880-A | ME-09 | 152.2 | 21925.8 | 196 | 21925.8 | 31.54 | 0.00 | -5,203 | 0 | -5,203 |
| | 220kV BYRNIHAT-MISA | NP-9092-A | AS-70 | 89787.1 | 85965.9 | 89787.1 | 85965.9 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 220kV BYRNIHAT-MISA II | NP-9091-A | AS-72 | 83552.6 | 96033.2 | 83552.6 | 96033.1 | 0.00 | -0.16 | 0 | -26 | -26 |
| | 400kV BYRNIHAT-B'GAON | NP-8370-A | ME-14 | 3916.9 | 99953.7 | 2831.8 | 99953.7 | -3,945.82 | 0.00 | -651,060 | 0 | -651,060 |
| | 400kV BYRNIHAT-SILCHAR | NP-8371-A | ME-15 | 25607.2 | 99864 | 25728.2 | 99864 | 440.00 | 0.00 | 72,600 | 0 | 72,600 |
| TOTAL | | | | | | | | | | | | -593,859 |

| | | | | | | | | | | | | |
|--------------|---------------------------|-----------|-------|---------|---------|---------|---------|--------|------|-------|-------|--------------|
| MIZORAM | 132kV LAUNGMUAL-AIZWAL PG | NP-9495-A | MZ-02 | 450.5 | 6980.3 | 444.8 | 6998.1 | -2.05 | 6.41 | 339 | 1,057 | 1,396 |
| | 132kV ZUANGTUI-MELRIAT PG | NP-9563-A | MZ-14 | 70876.1 | 52526.1 | 70826.3 | 52528.1 | -17.93 | 0.72 | 2,958 | 119 | 3,077 |
| | 132kV KOLASIB-BADARPUR PG | NE-0086-A | MZ-11 | 329.7 | 99805.6 | 320.8 | 99805.6 | -3.20 | 0.00 | -529 | 0 | -529 |
| | 132kV KOLASIB-AIZAWL PG | NE-0087-A | MZ-12 | 493.8 | 33.6 | 533.7 | 33.6 | 28.73 | 0.00 | 4,740 | 0 | 4,740 |
| TOTAL | | | | | | | | | | | | 8,684 |

| | | | | | | | | | | | | |
|--------------|-------------------------|-----------|-------|---------|---------|---------|---------|------|------|---|----|----------|
| NAGALAND | 132kV DIMAPUR S-PG I | NP-9602-A | NG-01 | 17198.6 | 9491.9 | 17198.6 | 9492 | 0.00 | 0.10 | 0 | 16 | 16 |
| | 132kV DIMAPUR S-PG II | NP-9649-A | NG-17 | 74609.2 | 4553.7 | 74609.2 | 4553.7 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV KOHIMA-DIMAPUR PG | NP-8472-A | NG-16 | 6292.8 | 98285.5 | 6292.8 | 98285.5 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV M'CHANG S-PG I | NP-9653-A | NG-20 | 44494.4 | 4873.7 | 44494.4 | 4873.8 | 0.00 | 0.04 | 0 | -6 | -6 |
| | 132kV M'CHANG S-PG II | NP-9655-A | NG-21 | 43909.1 | 4955.1 | 43909.1 | 4955.2 | 0.00 | 0.04 | 0 | -6 | -6 |
| TOTAL | | | | | | | | | | | | 4 |


| | | | | | | | | | | | | |
|---------|--|-----------|-------|---------|---------|---------|---------|-------|-------|-----|----|-----|
| TRIPURA | 132kV PK BARI-KUMARGHAT | NP-6860-A | TR-04 | 97414 | 84658.6 | 97414 | 84658.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI-SILCHAR I | NP-9709-A | TR-15 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI-SILCHAR II | NP-9710-A | TR-16 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Agartala-AGTPP Ckt I | NP-6850-A | TR-01 | 8511.7 | 6224.9 | 8511.7 | 6224.8 | 0.00 | -0.10 | 0 | 16 | 16 |
| | 132kV Agartala-AGTPP Ckt II | NP-6851-A | TR-02 | 48156.6 | 93754.6 | 48156.6 | 93754.5 | 0.00 | -0.10 | 0 | 16 | 16 |
| | 132kV SM Nagar-Palatana | NP-8471-A | TR-13 | 68831.1 | 72313.3 | 68831.1 | 72313.2 | 0.00 | -0.12 | 0 | 20 | 20 |
| | 132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE) | NP-9893-A | TR-28 | 7360.5 | 99970.6 | 7360.5 | 99970.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE) | NP-9890-A | TR-29 | 14710.8 | 26.3 | 14710.8 | 26.3 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI (TSECL) - PK BARI (STERLITE) | NP-9931-A | TR-24 | 10452.2 | 99994.9 | 10452.5 | 99994.9 | 0.29 | 0.00 | -48 | 0 | -48 |
| | 132kV AMBASSA (TSECL) - PK BARI (STERLITE) | NP-9930-A | TR-25 | 4799.6 | 99999.7 | 4799.4 | 99999.7 | -0.19 | 0.00 | 32 | 0 | 32 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT I | NP-9933-A | TR-21 | 1468.8 | 99976.9 | 1468.8 | 99976.7 | 0.00 | -0.19 | 0 | 32 | 32 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT II | NP-9932-A | TR-22 | 1356.9 | 99997.2 | 1356.9 | 99997.2 | 0.00 | 0.00 | 0 | 0 | 0 |
| | TOTAL | | | | | | | | | | | |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/kVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम. अल्मोल/S.M. Almol)
 निदेशक/Director
 उत्तु क्षेत्र/NERPC
 विद्युत विभाग/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 6/12/2023 to 6/18/2023


| Beneficiary | Line Name | To Beneficiary | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | Effective Net Reactive Charge |
|-------------------------|---------------------|----------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|-------------------------------|
| | | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | |
| ASSAM | KAHELIPARA-UMTRU II | MEGHALAYA | NE-0089-A | AS-02 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NE-0016-A | ME-04 | 0.6 | 0 | 0.6 | 0 | 0 | 0 | 0 | 0 | |
| | KAHELIPARA-UMTRU I | MEGHALAYA | NE-0088-A | AS-01 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8474-A | ME-03 | 99244 | 99984.8 | 99244 | 99984.8 | 0 | 0 | 0 | 0 | |
| | S'SUJAI-UMTRU I | MEGHALAYA | NP-9921-A | AS-09 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8473-A | ME-07 | 92616.3 | 99820.2 | 92612.3 | 99820.2 | -1.92 | 0 | -317 | 0 | |
| | S'SUJAI-UMTRU II | MEGHALAYA | NP-9922-A | AS-50 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8491-A | ME-05 | 93516.6 | 99794.7 | 93512.6 | 99794.7 | -1.92 | 0 | -317 | 0 | |
| | PANCHGRAM-LUMSHONG | MEGHALAYA | NP-7595-A | AS-06 | 87836.2 | 1085.1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8384-A | ME-01 | 94398.7 | 60784.9 | 94342.7 | 60784.9 | -26.88 | 0 | -4,435 | 0 | |
| | AGIA-Mendhipathar | MEGHALAYA | NP-9455-A | AS-86 | 76290.4 | 6669 | 75706.5 | 6669 | -280.272 | 0 | -46,245 | 0 | -29,375 |
| | | | NP-9071-A | ME-16 | 89506.9 | 21625.4 | 89877.8 | 21622.6 | 178.032 | -1.344 | 29,375 | 222 | |
| 132 KV AGIA-NANGALBIBRA | MEGHALAYA | NP-9920-A | AM-58 | 68858.2 | 86.1 | 68206.5 | 86.1 | -234.612 | 0 | -38,711 | 0 | -2,572 | |
| | | NP-9945-A | ME-17 | 43.7 | 91513.8 | 87 | 91489.4 | 15.588 | -8.784 | 2,572 | 1,449 | | |
| TOTAL | | | | | | | | | | | | | -31,947 |
| ASSAM | D'CHERRA - D'NAGAR | TRIPURA | NP-9904-A | AS-08 | 21241.6 | 99662 | 21323.1 | 99662.1 | 39.12 | 0.048 | 6,455 | -8 | -8 |
| | | | NP-6892-B | TR-06 | 76269 | 48789.3 | 76269 | 48527.7 | 0 | -125.568 | 0 | 20,719 | |
| TOTAL | | | | | | | | | | | | | -8 |
| MANIPUR | 132KV KARONG-KOHIMA | NAGALAND | NP-9667-A | MN-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-9947-A | NG-02 | 1737.6 | 99852.2 | 1738 | 99852.2 | 0.192 | 0 | 32 | 0 | |
| TOTAL | | | | | | | | | | | | | 0 |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/kVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S.M. Aisool) / S.M. Aisool
 निदेशक / Director
 उत्तरी क्षेत्र / NERPC
 विद्युत मंत्रालय / Min. of Power
 भारत सरकार / Govt. of India
 शिलांग / Shillong


Reactive Energy (VArH) Charge Statement
for the period 6/19/2023 to 6/25/2023

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

| BENEFICIARY | AMOUNT PAYABLE TO POOL(Rs.) | AMOUNT RECEIVABLE FROM POOL (Rs.) |
|--------------------|------------------------------------|--|
| ARUNACHAL PRADESH | 5,172 | 0 |
| ASSAM | 0 | 44,243 |
| MANIPUR | 17,419 | 0 |
| MEGHALAYA | 0 | 552,520 |
| MIZORAM | 588 | 0 |
| NAGALAND | 1,661 | 0 |
| TRIPURA | 0 | 0 |

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

| RECEIVABLE BENEFICIARY | FROM BENEFICIARY | AMOUNT RECEIVABLE (Rs.) |
|-------------------------------|-------------------------|--------------------------------|
| ASSAM | MEGHALAYA | 27,318 |
| ASSAM | TRIPURA | 0 |
| MANIPUR | NAGALAND | 0 |
| MEGHALAYA | ASSAM | 0 |
| NAGALAND | MANIPUR | 0 |
| TRIPURA | ASSAM | 0 |



(एस.एम.आइमोल/S.M.Aimol)
निदेशक/Director
उत्प्रेक्षित बिज/NERPC
विद्युत मंत्रालय/Min. of Power
भारत सरकार/Govt. of India
शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 6/19/2023 to 6/25/2023

| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|----------------------------|----------------------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| ARUNACHAL PRADESH | 132kV Ziro-Ranganadi | NP-9704-A | AR-06 | 52455.4 | 43.7 | 52455.4 | 43.7 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Khupi-Balipara | NP-9606-A | AS-55 | 24220.9 | 79.9 | 24183.9 | 79.9 | -13.32 | 0.00 | 2,198 | 0 | 2,198 |
| | 132kV Lekhi-Nirjuli | NP-9665-A | AR-10 | 1162.8 | 27032.5 | 1162.8 | 27032.6 | 0.00 | 0.07 | 0 | -12 | -12 |
| | Nirjuli-TRF 1 | NP-9661-A | AR-01 | 460.8 | 8137.4 | 460.8 | 8162.5 | 0.00 | 9.04 | 0 | 1,491 | 1,491 |
| | Nirjuli-TRF 2 | NP-9662-A | AR-02 | 557.6 | 6824.7 | 557.6 | 6849.6 | 0.00 | 8.96 | 0 | 1,479 | 1,479 |
| | 132kV Tenga-Balipara | NP-9696-A | AR-17 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Lekhi-Pare | NP-9607-A | PA-01 | 58725.3 | 224.8 | 58725.3 | 224.8 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Chimpu-Pare | NP-9411-A | PA-05 | 2892.2 | 99972.9 | 2892.2 | 99972.9 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV ITANAGAR - BNC FDR 1 | NP-9935-A | AR-19 | 813 | 99436.5 | 813 | 99436.5 | 0.00 | 0.00 | 0 | 0 | 0 |
| 132kV ITANAGAR - BNC FDR 2 | NP-9939-A | AR-20 | 334.8 | 99483.6 | 334.8 | 99483.5 | 0.00 | -0.10 | 0 | 16 | 16 | |
| TOTAL | | | | | | | | | | | | 5,172 |

| | | | | | | | | | | | | | |
|-------|-------------------------------------|-----------|-------|---------|---------|---------|---------|-----------|---------|----------|---------|----------|----------------|
| ASSAM | 220kV BTPS-II - SALAKATI | NE-0064-A | AS-31 | 401.7 | 0.8 | 251.6 | 0.8 | -240.16 | 0.00 | 39,626 | 0 | 39,626 | |
| | 220kV BTPS-I - SALAKATI | NP-9434-A | AS-30 | 39013 | 6863 | 38906.2 | 6863 | -170.88 | 0.00 | 28,195 | 0 | 28,195 | |
| | 220kV SAMAGURI-I - MISA | NP-9583-A | AS-17 | 94259.2 | 98606 | 94259.2 | 98606.1 | 0.00 | 0.10 | 0 | -17 | -17 | |
| | 220kV SAMAGURI-II - MISA | NP-9713-A | AS-18 | 13055.1 | 99216.1 | 13061.1 | 99216.2 | 6.00 | 0.10 | 990 | -17 | 974 | |
| | 220kV SONABIL-BALIPARA | NP-9487-A | AS-42 | 38205.2 | 64 | 38198.9 | 64 | -10.08 | 0.00 | 1,663 | 0 | 1,663 | |
| | 220kV MARIANI - MISA | NP-9700-A | AS-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV PANCHGRAM-B'PUR(PG) | NP-6872-A | AS-07 | 6450.9 | 79845.9 | 6407.4 | 79845.9 | -31.32 | 0.00 | -5,168 | 0 | -5,168 | |
| | 132kV P'pool-JIRIBAM | NE-0039-A | MN-06 | 8130.6 | 19.9 | 8147.2 | 19.9 | 11.95 | 0.00 | -1,972 | 0 | -1,972 | |
| | 132kV GOHPUR-NIRJULI | NP-9688-A | AS-13 | 99501.8 | 82255 | 99501.8 | 82282.8 | 0.00 | 10.01 | 0 | -1,651 | -1,651 | |
| | HAF LONG CONSUMPTION | NP-8494-A | AS-11 | 21966.1 | 3359.2 | 21974.9 | 3359.2 | 1.58 | 0.00 | -261 | 0 | -261 | |
| | 132kV HAILAKANDI-SILCHAR-I | NP-5301-A | AS-79 | 75840 | 91177.1 | 75840 | 91177.1 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV HAILAKANDI-SILCHAR 2 | NP-9478-A | AS-80 | 80705.1 | 99934.5 | 80705.1 | 99934.4 | 0.00 | -0.04 | 0 | 6 | 6 | |
| | 132kV SONABIL-BALIPARA | NP-6150-A | AS-57 | 5597.8 | 69869.5 | 5597.8 | 69869.5 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV DEPOTA-BALIPARA | NP-6149-A | AS-56 | 58011.8 | 72679.3 | 58011.8 | 72679.3 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV SRIKONA-SILCHAR ckt I | NP-9712-A | AS-77 | 79769.7 | 99980.1 | 79769.7 | 99980.1 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV SRIKONA-SILCHAR ckt2 | NP-9711-A | AS-78 | 68869.4 | 99985.5 | 68869.4 | 99985.5 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV BOKAJAN-DIMAPUR | NP-9675-A | NG-08 | 29962.8 | 1532.8 | 29962.8 | 1531.3 | 0.00 | -1.44 | 0 | -238 | -238 | |
| | 400kV AZARA-BONGAIGAON | NP-9983-A | AM-01 | 92625.3 | 99786.4 | 92623.8 | 99786.4 | -10.91 | 0.00 | -1,800 | 0 | -1,800 | |
| | 400kV AZARA-SILCHAR | NP-9981-A | AS-93 | 1398.3 | 97603.1 | 1398.4 | 97603.7 | 0.73 | 0.00 | 120 | 0 | 120 | |
| | 132kV RANGIA-MOTANGA | NP-9669-A | AS-73 | 87188.2 | 92716.3 | 87309 | 93089.2 | 43.49 | 134.24 | 7,176 | -22,150 | -14,975 | |
| | 220kV Mariani-AGBPP | NP-6888-A | AS-03 | 74301.2 | 96335.2 | 73673.1 | 96335.2 | -1,004.96 | 0.00 | -165,818 | 0 | -165,818 | |
| | 132kV KARIMGANJ - BADARPUR | NP-9690-A | AM-53 | 93548.1 | 98821.3 | 93548.1 | 98791.1 | 0.00 | -21.74 | 0 | 3,588 | 3,588 | |
| | 132kV KARIMGANJ - KUMARGHAT | NP-9937-A | AM-54 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV Umrangshu - Khandong | NP-5290-A | AM-04 | 78839.3 | 98968.5 | 79286.2 | 98968.5 | 214.51 | 0.00 | 35,394 | 0 | 35,394 | |
| | 132kV Umrangshu - Haflong | NE-0019-A | AM-05 | 80645.6 | 99316.5 | 80263.6 | 99316.5 | -183.36 | 0.00 | -30,254 | 0 | -30,254 | |
| | 132kV PavoI - BNC Ckt I | NP-9680-A | AM-12 | 15790.4 | 69624.6 | 15790.4 | 69061.2 | 0.00 | -202.82 | 0 | 33,466 | 33,466 | |
| | 132kV PavoI - BNC Ckt II | NP-8801-A | AM-13 | 50307.1 | 64488.7 | 50307.1 | 63900.5 | 0.00 | -211.75 | 0 | 34,939 | 34,939 | |
| | Balipara end of 400 kV Bongaigaon-1 | NE-0043-A | ZZ-16 | 90035.6 | 99950.9 | 90035.6 | 99950.8 | 0.00 | -0.36 | 0 | -60 | -60 | |
| | Balipara end of 400 kV Bongaigaon-2 | NE-0047-A | ZZ-17 | 86907.4 | 2 | 86907.4 | 2 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | TOTAL | | | | | | | | | | | | -44,243 |

| | | | | | | | | | | | | |
|--------------|------------------------------------|-----------|-------|---------|---------|---------|---------|---------|-------|--------|----|---------------|
| MANIPUR | 132kV Imp(S)-Imp(PG) Ckt II | NP-9546-A | MN-23 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Imp(S)-Imp(PG) Ckt I | NP-9544-A | ZZ-01 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | JIRIBAM-TRF | NP-8501-A | MN-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV JIRIBAM (S) - Jiribam (PG) | NP-9523-A | MN-12 | 98470.6 | 99869.3 | 98470.4 | 99869.3 | -0.07 | 0.00 | 12 | 0 | 12 |
| | IMPHAL (PG) ICT I | NP-9520-A | MN-13 | 22176.2 | 384.6 | 22183.5 | 384.6 | 2.63 | 0.00 | -434 | 0 | -434 |
| | IMPHAL (PG) ICT II | NP-9522-A | MN-14 | 19679.1 | 384.1 | 19685.7 | 384.1 | 2.38 | 0.00 | -392 | 0 | -392 |
| | 132kV NINGTHOUKHONG-IMPHAL (PG) | NP-9518-A | MN-10 | 41912.5 | 99419.5 | 41906.6 | 99419.4 | -2.12 | -0.04 | 350 | -6 | 345 |
| | 132kV Imp(S)-Imp(PG) Ckt III | NP-9689-A | MN-22 | 93842.2 | 19.4 | 93839.1 | 19.4 | -2.23 | 0.00 | 368 | 0 | 368 |
| | 400kV THOUBAL-IMPHAL(PG) 1 | NP-9547-A | MN-24 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 400kV THOUBAL-IMPHAL(PG) 2 | NP-9543-A | MN-25 | 2942.1 | 0.4 | 2927.5 | 0.4 | -106.18 | 0.00 | 17,520 | 0 | 17,520 |
| | 132/33 50 MVA IMPHAL ICT 1 LV SIDE | NE-0048-A | ZZ-71 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132/33 50 MVA IMPHAL ICT 2 LV SIDE | NE-0018-A | ZZ-72 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Aizwal | NE-0169-A | MN-20 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Jiribam | NE-0167-A | MN-21 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| TOTAL | | | | | | | | | | | | 17,419 |


 (ए.एम. आइमो/S.M. Ailmo)
 निदेशक/Director
 उ.पू.वि.स./NEERC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 दिल्ली/Shillong

| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|--------------|--|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| MEGHALAYA | 132kV KHLRT S-PG | NP-6865-A | ME-02 | 94018.9 | 80696.4 | 93976.6 | 80696.4 | -30.46 | 0.00 | -5,025 | 0 | -5,025 |
| | 132kV KHLRT S-PG II | NP-6880-A | ME-09 | 199.9 | 21925.8 | 199.7 | 21929.4 | -0.14 | 2.59 | 24 | 428 | 451 |
| | 220kV BYRNIHAT-MISA | NP-9092-A | AS-70 | 89787.1 | 85965.9 | 89787.1 | 85965.8 | 0.00 | -0.16 | 0 | -26 | -26 |
| | 220kV BYRNIHAT-MISA II | NP-9091-A | AS-72 | 83552.6 | 96033.1 | 83552.6 | 96033.1 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 400kV BYRNIHAT-B'GAON | NP-8370-A | ME-14 | 2571.4 | 99953.7 | 1297.1 | 99953.7 | -4,633.82 | 0.00 | -764,580 | 0 | -764,580 |
| | 400kV BYRNIHAT-SILCHAR | NP-8371-A | ME-15 | 25833.8 | 99864 | 26194.9 | 99864 | 1,313.09 | 0.00 | 216,660 | 0 | 216,660 |
| TOTAL | | | | | | | | | | | | -552,520 |
| MIZORAM | 132kV LAUNGUAL-AIZWAL PG | NP-9495-A | MZ-02 | 444.8 | 6998.1 | 444.8 | 7009.6 | 0.00 | 4.14 | 0 | 683 | 683 |
| | 132kV ZUANGTUI-MELRIAT PG | NP-9563-A | MZ-14 | 70826.3 | 52528.9 | 70826.3 | 52530.5 | 0.00 | 0.58 | 0 | 95 | 95 |
| | 132kV KOLASIB-BADARPUR PG | NE-0086-A | MZ-11 | 320.8 | 99805.6 | 320.8 | 99805.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV KOLASIB-AIZAWL PG | NE-0087-A | MZ-12 | 533.7 | 33.6 | 532.1 | 33.6 | -1.15 | 0.00 | -190 | 0 | -190 |
| TOTAL | | | | | | | | | | | 588 | |
| NAGALAND | 132kV DIMAPUR S-PG I | NP-9602-A | NG-01 | 17198.6 | 9492 | 17198.6 | 9499.6 | 0.00 | 7.30 | 0 | 1,204 | 1,204 |
| | 132kV DIMAPUR S-PG II | NP-9649-A | NG-17 | 74609.2 | 4553.7 | 74609.2 | 4567.7 | 0.00 | 10.08 | 0 | 1,663 | 1,663 |
| | 132kV KOHIMA-DIMAPUR PG | NP-8472-A | NG-16 | 6292.8 | 98285.5 | 6292.8 | 98270.7 | 0.00 | -5.33 | 0 | -879 | -879 |
| | 132kV M'CHANG S-PG I | NP-9653-A | NG-20 | 44494.4 | 4873.8 | 44494.4 | 4876.5 | 0.00 | 0.97 | 0 | -160 | -160 |
| | 132kV M'CHANG S-PG II | NP-9655-A | NG-21 | 43909.1 | 4955.2 | 43909.1 | 4958 | 0.00 | 1.01 | 0 | -166 | -166 |
| TOTAL | | | | | | | | | | | 1,661 | |
| TRIPURA | 132kV PK BARI-KUMARGHAT | NP-6860-A | TR-04 | 97414 | 84658.6 | 97414 | 84658.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI-SILCHAR I | NP-9709-A | TR-15 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI-SILCHAR II | NP-9710-A | TR-16 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Agartala-AGTPP Ckt I | NP-6850-A | TR-01 | 8509.9 | 6224.8 | 8509.9 | 6224.8 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Agartala-AGTPP Ckt II | NP-6851-A | TR-02 | 48156.2 | 93754.5 | 48156.2 | 93754.5 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV SM Nagar-Palatana | NP-8471-A | TR-13 | 68833.2 | 72313.2 | 68833.2 | 72313.2 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE) | NP-9893-A | TR-28 | 7360.5 | 99970.6 | 7360.5 | 99970.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE) | NP-9890-A | TR-29 | 14710.8 | 26.3 | 14710.8 | 26.3 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI (TSECL) - PK BARI (STERLITE) | NP-9931-A | TR-24 | 10452.5 | 99994.9 | 10452.5 | 99994.9 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV AMBASSA (TSECL) - PK BARI (STERLITE) | NP-9930-A | TR-25 | 4799.4 | 99999.7 | 4799.4 | 99999.7 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT I | NP-9933-A | TR-21 | 1468.8 | 99976.7 | 1468.8 | 99976.7 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT II | NP-9932-A | TR-22 | 1356.9 | 99997.2 | 1356.9 | 99997.2 | 0.00 | 0.00 | 0 | 0 | 0 |
| | TOTAL | | | | | | | | | | | 0 |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/kVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.

M. M. M.
 (एस.एम. आइमल/S.M.Aimol)
 निदेशक/Director
 उ.पु.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 दिल्ली/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 6/19/2023 to 6/25/2023


| Beneficiary | Line Name | To Beneficiary | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | Effective Net Reactive Charge | |
|-------------------------|---------------------|----------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|-------------------------------|---------|
| | | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | | |
| ASSAM | KAHELIPARA-UMTRU II | MEGHALAYA | NE-0089-A | AS-02 | 98246.7 | 99782.6 | 98219.2 | 99777.6 | -13.2 | -2.4 | -2,178 | 396 | 0 | |
| | | | NE-0016-A | ME-04 | 0.6 | 0 | 0.6 | 0 | 0 | 0 | 0 | 0 | | 0 |
| | KAHELIPARA-UMTRU I | MEGHALAYA | NE-0088-A | AS-01 | 97588 | 99641 | 97553 | 99632.6 | -16.8 | -4.032 | -2,772 | 665 | 0 | |
| | | | NP-8474-A | ME-03 | 99244 | 99984.8 | 99244 | 99984.8 | 0 | 0 | 0 | 0 | | 0 |
| | S'SUJAI-UMTRU I | MEGHALAYA | NP-9921-A | AS-09 | 99982.6 | 0.3 | 99982.6 | 0.3 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8473-A | ME-07 | 92612.3 | 99820.2 | 92609.4 | 99820.2 | -1.392 | 0 | -230 | 0 | 0 | |
| | S'SUJAI-UMTRU II | MEGHALAYA | NP-9922-A | AS-50 | 99987.8 | 0 | 99987.8 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8491-A | ME-05 | 93512.6 | 99794.7 | 93509.7 | 99794.7 | -1.392 | 0 | -230 | 0 | 0 | |
| | PANCHGRAM-LUMSHONG | MEGHALAYA | NP-7595-A | AS-06 | 87836.2 | 1085.1 | 87836.2 | 1085.1 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8384-A | ME-01 | 94337.4 | 60784.9 | 94340.6 | 60774.7 | 1.536 | -4.896 | 253 | 808 | 0 | |
| | AGIA-Mendhipathar | MEGHALAYA | NP-9455-A | AS-86 | 75575.5 | 6669 | 75040.2 | 6669 | -256.944 | 0 | -42,396 | 0 | 0 | -24,663 |
| | | | NP-9071-A | ME-16 | 89933.2 | 21622.6 | 90244.6 | 21622.7 | 149.472 | 0.048 | 24,663 | -8 | 0 | |
| 132 KV AGIA-NANGALBIBRA | MEGHALAYA | NP-9920-A | AM-58 | 68016.4 | 86.1 | 67314.5 | 86.1 | -252.684 | 0 | -41,693 | 0 | 0 | -2,655 | |
| | | NP-9945-A | ME-17 | 30 | 91489.4 | 74.7 | 91487.4 | 16.092 | -0.72 | 2,655 | 119 | 0 | | |
| TOTAL | | | | | | | | | | | | | -27,318 | |
| ASSAM | D'CHERRA - D'NAGAR | TRIPURA | NP-9904-A | AS-08 | 21323.1 | 99662.1 | 21323.1 | 99662.1 | 0 | 0 | 0 | 0 | 0 | |
| TOTAL | | | NP-6892-B | TR-06 | 76269 | 48520.4 | 76269 | 48509.4 | 0 | -5.28 | 0 | 871 | 0 | |
| MANIPUR | 132KV KARONG-KOHIMA | NAGALAND | NP-9667-A | MN-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| TOTAL | | | NP-9947-A | NG-02 | 1738 | 99852.2 | 1739.3 | 99851.4 | 0.624 | -0.384 | 103 | 63 | 0 | |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S.M. Aimol) /S.M. Aimol
 निदेशक/Director
 उत्तु.शे.वि.श./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong


**Reactive Energy (VArH) Charge Statement
for the period 6/26/2023 to 7/2/2023**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

| BENEFICIARY | AMOUNT PAYABLE TO POOL(Rs.) | AMOUNT RECEIVABLE FROM POOL (Rs.) |
|--------------------|------------------------------------|--|
| ARUNACHAL PRADESH | 1,396 | 0 |
| ASSAM | 0 | 57,252 |
| MANIPUR | 43,591 | 0 |
| MEGHALAYA | 0 | 265,391 |
| MIZORAM | 4,538 | 0 |
| NAGALAND | 319 | 0 |
| TRIPURA | 0 | 12,925 |

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

| RECEIVABLE BENEFICIARY | FROM BENEFICIARY | AMOUNT RECEIVABLE (Rs.) |
|-------------------------------|-------------------------|--------------------------------|
| ASSAM | MEGHALAYA | 31,684 |
| ASSAM | TRIPURA | 0 |
| MANIPUR | NAGALAND | 0 |
| MEGHALAYA | ASSAM | 0 |
| NAGALAND | MANIPUR | 0 |
| TRIPURA | ASSAM | 0 |



 (एस.एम.आइमोन/S.M.Aimon)
 निदेशक/Director
 उ.पू.के.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 6/26/2023 to 7/2/2023

| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|----------------------------|----------------------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| ARUNACHAL PRADESH | 132kV Ziro-Ranganadi | NP-9704-A | AR-06 | 52455.4 | 43.7 | 52455.4 | 43.7 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Khupi-Balipara | NP-9606-A | AS-55 | 24180.1 | 79.9 | 24148.4 | 79.9 | -11.41 | 0.00 | 1,883 | 0 | 1,883 |
| | 132kV Lekhi-Nirjuli | NP-9665-A | AR-10 | 1162.8 | 27032.6 | 1162.8 | 27032.9 | 0.00 | 0.22 | 0 | -36 | -36 |
| | Nirjuli-TRF 1 | NP-9661-A | AR-01 | 460.8 | 8163.3 | 460.8 | 8182 | 0.00 | 6.73 | 0 | 1,111 | 1,111 |
| | Nirjuli-TRF 2 | NP-9662-A | AR-02 | 557.6 | 6850.3 | 557.6 | 6867.8 | 0.00 | 6.30 | 0 | 1,040 | 1,040 |
| | 132kV Tenga-Balipara | NP-9696-A | AR-17 | 44200.7 | 6.4 | 44178.8 | 6.4 | -15.77 | 0.00 | -2,602 | 0 | -2,602 |
| | 132kV Lekhi-Pare | NP-9607-A | PA-01 | 58725.3 | 224.8 | 58725.3 | 224.8 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Chimpu-Pare | NP-9411-A | PA-05 | 2892.2 | 99972.9 | 2892.2 | 99972.9 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV ITANAGAR - BNC FDR 1 | NP-9935-A | AR-19 | 813 | 99436.5 | 813 | 99436.5 | 0.00 | 0.00 | 0 | 0 | 0 |
| 132kV ITANAGAR - BNC FDR 2 | NP-9939-A | AR-20 | 334.8 | 99483.5 | 334.8 | 99483.5 | 0.00 | 0.00 | 0 | 0 | 0 | |
| TOTAL | | | | | | | | | | | | 1,396 |

| | | | | | | | | | | | | | |
|-------|-------------------------------------|-----------|-------|---------|---------|---------|---------|---------|---------|----------|--------|----------|----------------|
| ASSAM | 220kV BTPS-II - SALAKATI | NE-0064-A | AS-31 | 276.5 | 0.8 | 305.2 | 0.8 | 45.92 | 0.00 | -7,577 | 0 | -7,577 | |
| | 220kV BTPS-I - SALAKATI | NP-9434-A | AS-30 | 38938.7 | 6863 | 38963.8 | 6863 | 40.16 | 0.00 | -6,626 | 0 | -6,626 | |
| | 220kV SAMAGURI-I - MISA | NP-9583-A | AS-17 | 94261.6 | 98606.1 | 94261.6 | 98606.1 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 220kV SAMAGURI-II - MISA | NP-9713-A | AS-18 | 13062.6 | 99216.2 | 13063.9 | 99216.2 | 1.30 | 0.00 | 215 | 0 | 215 | |
| | 220kV SONABIL-BALIPARA | NP-9487-A | AS-42 | 38201.7 | 64 | 38194.8 | 64 | -11.04 | 0.00 | 1,822 | 0 | 1,822 | |
| | 220kV MARIANI - MISA | NP-9700-A | AS-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV PANCHGRAM-B'PUR(PG) | NP-6872-A | AS-07 | 6345.9 | 79845.9 | 6132.6 | 79845.8 | -153.58 | -0.07 | -25,340 | 12 | -25,328 | |
| | 132kV P'pool-JIRIBAM | NE-0039-A | MN-06 | 8168.4 | 19.9 | 8208.1 | 19.9 | 28.58 | 0.00 | -4,716 | 0 | -4,716 | |
| | 132kV GOHPUR-NIRJULI | NP-9688-A | AS-13 | 99501.8 | 82282.8 | 99501.8 | 82296.9 | 0.00 | 5.08 | 0 | -838 | -838 | |
| | HAF LONG CONSUMPTION | NP-8494-A | AS-11 | 21977 | 3359.2 | 21986.1 | 3359.2 | 1.64 | 0.00 | -270 | 0 | -270 | |
| | 132kV HAILAKANDI-SILCHAR-I | NP-5301-A | AS-79 | 75822.9 | 91177.1 | 75804.1 | 91177.1 | -6.77 | 0.00 | -1,117 | 0 | -1,117 | |
| | 132kV HAILAKANDI-SILCHAR 2 | NP-9478-A | AS-80 | 80688.1 | 99934.4 | 80671.1 | 99934.4 | -6.12 | 0.00 | -1,010 | 0 | -1,010 | |
| | 132kV SONABIL-BALIPARA | NP-6150-A | AS-57 | 5597.8 | 69869.5 | 5597.8 | 69869.5 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV DEPOTA-BALIPARA | NP-6149-A | AS-56 | 58011.8 | 72679.3 | 58011.8 | 72679.3 | 0.00 | 0.00 | 0 | 0 | 0 | |
| | 132kV SRIKONA-SILCHAR ckt I | NP-9712-A | AS-77 | 79744.5 | 99980.1 | 79701.5 | 99980.1 | -15.48 | 0.00 | -2,554 | 0 | -2,554 | |
| | 132kV SRIKONA-SILCHAR ckt2 | NP-9711-A | AS-78 | 68832.1 | 99985.5 | 68754.4 | 99985.5 | -27.97 | 0.00 | -4,615 | 0 | -4,615 | |
| | 132kV BOKAJAN-DIMAPUR | NP-9675-A | NG-08 | 29961.7 | 1531.3 | 29961.7 | 1531.9 | 0.00 | 0.58 | 0 | 95 | 95 | |
| | 400kV AZARA-BONGAIGAON | NP-9983-A | AM-01 | 92623.8 | 99786.4 | 92620 | 99786.4 | -27.64 | 0.00 | -4,560 | 0 | -4,560 | |
| | 400kV AZARA-SILCHAR | NP-9981-A | AS-93 | 1398.1 | 1385.2 | 1385.2 | 97603.7 | -93.82 | 0.00 | -15,480 | 0 | -15,480 | |
| | 132kV RANGIA-MOTANGA | NP-9669-A | AS-73 | 87340.8 | 93089.1 | 87372.4 | 93161.5 | 11.38 | 26.06 | 1,877 | -4,301 | -2,424 | |
| | 220kV Mariani-AGBPP | NP-6888-A | AS-03 | 73465.1 | 96335.2 | 72860.9 | 96335.2 | -966.72 | 0.00 | -159,509 | 0 | -159,509 | |
| | 132kV KARIMGANJ - BADARPUR | NP-9690-A | AM-53 | 93548.1 | 98791.1 | 93548.1 | 98791 | 0.00 | -0.07 | 0 | 12 | 12 | |
| | 132kV KARIMGANJ - KUMARGHAT | NP-9937-A | AM-54 | 4861.7 | 5876.4 | 4862.2 | 5875.7 | 0.36 | -0.50 | 59 | 83 | 143 | |
| | 132kV Umrangshu - Khandong | NP-5290-A | AM-04 | 79416.7 | 98968.5 | 79809.3 | 98968.5 | 188.45 | 0.00 | 31,094 | 0 | 31,094 | |
| | 132kV Umrangshu - Haflong | NE-0019-A | AM-05 | 80152.6 | 99316.5 | 79768.2 | 99316.5 | -184.51 | 0.00 | -30,444 | 0 | -30,444 | |
| | 132kV PavoI - BNC Ckt I | NP-9680-A | AM-12 | 15790.4 | 68841.4 | 15790.4 | 67385 | 0.00 | -524.30 | 0 | 86,510 | 86,510 | |
| | 132kV PavoI - BNC Ckt II | NP-8801-A | AM-13 | 50307.1 | 63675.3 | 50307.1 | 62172.5 | 0.00 | -541.01 | 0 | 89,266 | 89,266 | |
| | Balipara end of 400 kV Bongaigaon-1 | NE-0043-A | ZZ-16 | 90038.9 | 99950.8 | 90037.9 | 99950.8 | -3.64 | 0.00 | 600 | 0 | 600 | |
| | Balipara end of 400 kV Bongaigaon-2 | NE-0047-A | ZZ-17 | 86910.9 | 2 | 86910.8 | 2 | -0.36 | 0.00 | 60 | 0 | 60 | |
| | TOTAL | | | | | | | | | | | | -57,252 |

| | | | | | | | | | | | | |
|---------|------------------------------------|-----------|-------|---------|---------|---------|---------|---------|------|--------|---|--------|
| MANIPUR | 132kV Imp(S)-Imp(PG) Ckt II | NP-9546-A | MN-23 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Imp(S)-Imp(PG) Ckt I | NP-9544-A | ZZ-01 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | JIRIBAM-TRF | NP-8501-A | MN-04 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV JIRIBAM (S) - Jiribam (PG) | NP-9523-A | MN-12 | 98473.5 | 99869.3 | 98476.2 | 99869.3 | 0.97 | 0.00 | -160 | 0 | -160 |
| | IMPHAL (PG) ICT I | NP-9520-A | MN-13 | 22193.9 | 384.6 | 22210.7 | 384.6 | 6.05 | 0.00 | -998 | 0 | -998 |
| | IMPHAL (PG) ICT II | NP-9522-A | MN-14 | 19696 | 384.1 | 19712.5 | 384.1 | 5.94 | 0.00 | -980 | 0 | -980 |
| | 132kV NINGTHOUKHONG-IMPHAL (PG) | NP-9518-A | MN-10 | 41879.7 | 99419.4 | 41843.9 | 99419.4 | -12.89 | 0.00 | 2,127 | 0 | 2,127 |
| | 132kV Imp(S)-Imp(PG) Ckt III | NP-9689-A | MN-22 | 93833.7 | 19.4 | 93829.3 | 19.4 | -3.17 | 0.00 | 523 | 0 | 523 |
| | 400kV THOUBAL-IMPHAL(PG) 1 | NP-9547-A | MN-24 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 400kV THOUBAL-IMPHAL(PG) 2 | NP-9543-A | MN-25 | 2913 | 0.4 | 2877.1 | 0.4 | -261.09 | 0.00 | 43,080 | 0 | 43,080 |
| | 132/33 50 MVA IMPHAL ICT 1 LV SIDE | NE-0048-A | ZZ-71 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132/33 50 MVA IMPHAL ICT 2 LV SIDE | NE-0018-A | ZZ-72 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Aizwal | NE-0169-A | MN-20 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Tipaimukh end of Jiribam | NE-0167-A | MN-21 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | TOTAL | | | | | | | | | | | |


 (ए.एम.आ.अ.नि.एम./S.M. Amini)
 निदेशक/Director
 उ.स.ओ.रे.ए./NERPC
 विद्युत शक्ति/Min. of Power
 भारत सरकार/Govt. of India
 दिल्ली/Delhi


| Beneficiary | Line Name | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | |
|--------------|--|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|---------------------|
| | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | Net Reactive Charge |
| MEGHALAYA | 132kV KHLRT S-PG | NP-6865-A | ME-02 | 93961.3 | 80696.4 | 93915.9 | 80696.4 | -32.69 | 0.00 | -5,394 | 0 | -5,394 |
| | 132kV KHLRT S-PG II | NP-6880-A | ME-09 | 202.8 | 21929.4 | 210.4 | 21929.4 | 5.47 | 0.00 | -903 | 0 | -903 |
| | 220kV BYRNIHAT-MISA | NP-9092-A | AS-70 | 89777.9 | 85965.8 | 89776.9 | 85965.8 | -1.60 | 0.00 | 264 | 0 | 264 |
| | 220kV BYRNIHAT-MISA II | NP-9091-A | AS-72 | 83542.5 | 96033.1 | 83540.6 | 96033.1 | -3.04 | 0.00 | 502 | 0 | 502 |
| | 400kV BYRNIHAT-B'GAON | NP-8370-A | ME-14 | 1292.1 | 99953.7 | 959.9 | 99953.7 | -1,208.00 | 0.00 | -199,320 | 0 | -199,320 |
| | 400kV BYRNIHAT-SILCHAR | NP-8371-A | ME-15 | 26142.5 | 99864 | 26041.6 | 99864 | -366.91 | 0.00 | -60,540 | 0 | -60,540 |
| TOTAL | | | | | | | | | | | | -265,391 |
| MIZORAM | 132kV LAUNGMUAL-AIZWAL PG | NP-9495-A | MZ-02 | 451.8 | 7009.6 | 456.2 | 7078.7 | 1.58 | 24.88 | -261 | 4,105 | 3,843 |
| | 132kV ZUANGTUI-MELRIAT PG | NP-9563-A | MZ-14 | 70806.4 | 52530.5 | 70794.9 | 52530.3 | -4.14 | -0.07 | 683 | -12 | 671 |
| | 132kV KOLASIB-BADARPUR PG | NE-0086-A | MZ-11 | 326.7 | 99805.6 | 331.1 | 99805.2 | 1.58 | -0.14 | 261 | 24 | 285 |
| | 132kV KOLASIB-AIZAWL PG | NE-0087-A | MZ-12 | 529.3 | 33.6 | 527.1 | 33.6 | -1.58 | 0.00 | -261 | 0 | -261 |
| TOTAL | | | | | | | | | | | | 4,538 |
| NAGALAND | 132kV DIMAPUR S-PG I | NP-9602-A | NG-01 | 17210.5 | 9499.6 | 17210.5 | 9500 | 0.00 | 0.38 | 0 | 63 | 63 |
| | 132kV DIMAPUR S-PG II | NP-9649-A | NG-17 | 74630.5 | 4567.7 | 74630.5 | 4568.5 | 0.00 | 0.58 | 0 | 95 | 95 |
| | 132kV KOHIMA-DIMAPUR PG | NP-8472-A | NG-16 | 6273.1 | 98270.7 | 6273.1 | 98270.7 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV M'CHANG S-PG I | NP-9653-A | NG-20 | 44494.4 | 4876.5 | 44494.4 | 4875.1 | 0.00 | -0.50 | 0 | 83 | 83 |
| | 132kV M'CHANG S-PG II | NP-9655-A | NG-21 | 43909.1 | 4958 | 43909.1 | 4956.7 | 0.00 | -0.47 | 0 | 77 | 77 |
| TOTAL | | | | | | | | | | | | 319 |
| TRIPURA | 132kV PK BARI-KUMARGHAT | NP-6860-A | TR-04 | 97414 | 84658.6 | 97414 | 84658.6 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI-SILCHAR I | NP-9709-A | TR-15 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI-SILCHAR II | NP-9710-A | TR-16 | 0 | 0 | 0 | 0 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV Agartala-AGTPP Ckt I | NP-6850-A | TR-01 | 8509.9 | 6224.8 | 8509.7 | 6224.8 | -0.19 | 0.00 | -32 | 0 | -32 |
| | 132kV Agartala-AGTPP Ckt II | NP-6851-A | TR-02 | 48156.2 | 93754.5 | 48156.2 | 93754.5 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV SM Nagar-Palatana | NP-8471-A | TR-13 | 68833.2 | 72313.2 | 68833.2 | 72313.2 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE) | NP-9893-A | TR-28 | 7366.8 | 99970.6 | 7372.2 | 99970.6 | 5.18 | 0.00 | -855 | 0 | -855 |
| | 132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE) | NP-9890-A | TR-29 | 14723.1 | 26.3 | 14732.8 | 26.3 | 9.31 | 0.00 | -1,536 | 0 | -1,536 |
| | 132kV PK BARI (TSECL) - PK BARI (STERLITE) | NP-9931-A | TR-24 | 10473.1 | 99994.9 | 10521.2 | 99994.9 | 46.18 | 0.00 | -7,619 | 0 | -7,619 |
| | 132kV AMBASSA (TSECL) - PK BARI (STERLITE) | NP-9930-A | TR-25 | 4809.8 | 99999.7 | 4828.2 | 99999.7 | 17.66 | 0.00 | -2,915 | 0 | -2,915 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT I | NP-9933-A | TR-21 | 1468.8 | 99976.7 | 1468.8 | 99976.7 | 0.00 | 0.00 | 0 | 0 | 0 |
| | 132kV PK BARI (TSECL) - AGTCCPP CKT II | NP-9932-A | TR-22 | 1358.1 | 99997.2 | 1358.3 | 99997.2 | 0.19 | 0.00 | 32 | 0 | 32 |
| TOTAL | | | | | | | | | | | | -12,925 |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/kVArH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (S. M. Amlol) / Director
 Director / Director
 बिजल विभाग / Min. of Power
 भारत सरकार / Govt. of India
 शिलांग / Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH OTHER UTILITIES
for the period 6/26/2023 to 7/2/2023


| Beneficiary | Line Name | To Beneficiary | Meter No. | Location ID | MVAR High Day 1 | MVAR Low Day 1 | MVAR High Day 7 | MVAR Low Day 7 | Actual*CT*PT | | Amount in Rs. | | Effective Net Reactive Charge |
|-------------------------|---------------------|----------------|-----------|-------------|-----------------|----------------|-----------------|----------------|--------------------|-------------------|------------------|-----------------|-------------------------------|
| | | | | | | | | | MVAR High For Week | MVAR Low For Week | MVAR High Charge | MVAR Low Charge | |
| ASSAM | KAHELIPARA-UMTRU II | MEGHALAYA | NE-0089-A | AS-02 | 98219.2 | 99776.2 | 98219.1 | 99763.6 | -0.048 | -6.048 | -8 | 998 | 0 |
| | | | NE-0016-A | ME-04 | 0.6 | 0 | 0.6 | 0 | 0 | 0 | 0 | 0 | |
| | KAHELIPARA-UMTRU I | MEGHALAYA | NE-0088-A | AS-01 | 97553 | 99629.6 | 97552.9 | 99608.9 | -0.048 | -9.936 | -8 | 1,639 | 0 |
| | | | NP-8474-A | ME-03 | 99244 | 99984.8 | 99244 | 99984.8 | 0 | 0 | 0 | 0 | |
| | S'SUJAI-UMTRU I | MEGHALAYA | NP-9921-A | AS-09 | 99982.6 | 0.3 | 99982.6 | 0.3 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8473-A | ME-07 | 92607.5 | 99820.2 | 92604 | 99820.2 | -1.68 | 0 | -277 | 0 | |
| | S'SUJAI-UMTRU II | MEGHALAYA | NP-9922-A | AS-50 | 99987.8 | 0 | 99987.8 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8491-A | ME-05 | 93507.8 | 99794.7 | 93504.3 | 99794.7 | -1.68 | 0 | -277 | 0 | |
| | PANCHGRAM-LUMSHONG | MEGHALAYA | NP-7595-A | AS-06 | 87836.2 | 1085.1 | 87836.2 | 1085.1 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-8384-A | ME-01 | 94337 | 60774.7 | 94334 | 60774.7 | -1.44 | 0 | -238 | 0 | |
| | AGIA-Mendhipathar | MEGHALAYA | NP-9455-A | AS-86 | 74975.1 | 6669 | 74756.8 | 6668.4 | -104.784 | -0.288 | -17,289 | 48 | -16,442 |
| | | | NP-9071-A | ME-16 | 90309.1 | 21621.3 | 90516.7 | 21614.5 | 99.648 | -3.264 | 16,442 | 539 | |
| 132 KV AGIA-NANGALBIBRA | MEGHALAYA | NP-9920-A | AM-58 | 67241.1 | 86.1 | 66984.5 | 75.5 | -92.376 | -3.816 | -15,242 | 630 | -15,242 | |
| | | NP-9945-A | ME-17 | 149.9 | 91481.4 | 452.4 | 91450 | 108.9 | -11.304 | 17,969 | 1,865 | | |
| TOTAL | | | | | | | | | | | | | -31,684 |
| ASSAM | D'CHERRA - D'NAGAR | TRIPURA | NP-9904-A | AS-08 | 21334.1 | 99662.1 | 21342.6 | 99662.1 | 4.08 | 0 | 673 | 0 | 0 |
| | | | NP-6892-B | TR-06 | 76269 | 48509.4 | 76269 | 48496.9 | 0 | -6 | 0 | 990 | |
| TOTAL | | | | | | | | | | | | | 0 |
| MANIPUR | 132KV KARONG-KOHIMA | NAGALAND | NP-9667-A | MN-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | NP-9947-A | NG-02 | 1741 | 99851.4 | 1740.5 | 99851.4 | -0.24 | 0 | -40 | 0 | |
| TOTAL | | | | | | | | | | | | | 0 |

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVAh

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

4) 'NA' means meter reading not available.


 (एस.एम. आइमल/S.M.Aimal)
 निदेशक/Director
 उ.पु.से.वि.स./NERPC
 विद्युत मंत्रालय/Min. of Power
 भारत सरकार/Govt. of India
 शिलांग/Shillong