



Government of India
Ministry of Power
North Eastern Regional Power Committee
Lapalang, Shillong 793006

No. NERPC/Dev/2022/3668-3690

Dt: 23rd August, 2023

सेवामें / To,

संलग्नसूचीकेअनुसार
As per list enclosed.

Sub: Reactive Energy Account under ABT regime-for the period 07.08.2023 to 13.08.2023- Reg.

सर/मैडम,
Sir/Madam.

The statement of Reactive Energy account giving details of payables/receivables with the pool and between beneficiaries in rupees for the period 07.08.2023 to 13.08.2023 is sent herewith. The rate for charge/payment for reactive energy will be governed as per clause 6.6 (2) of IEGC-April 2010 issue, which works out to be 16.5 Paise/KVARH w.e.f from 1st April 2023, computed @ 0.5 Paise escalation per year thereafter, unless otherwise revised by the Commission.

Further the payment by the constituents for the billed amount shall be made within ten days of the billing date. In case of delayed payment against these bills beyond twelve days, the defaulting constituents shall have to pay simple interest @ 0.04% for each day of delay vide clauses 11&12 under complimentary commercial mechanism of IEGC (April 2010) issue.

Utilities may please note that meter readings at both the ends are not available in case of some of the transmission lines and Reactive Energy account has been prepared based on available information.

Enclosed - As above.

भवदीय / Yours faithfully,

(अभिजीतअग्रवाल/ Abhijeet Agarwal)
उप निदेशक/Deputy Director
कार्यपालकअभियंता/Executive Engineer
वाणिज्य / Commercial

List of Addressees:

1. CMD, TSECL, Bidyut Bhawan, Agartala - 799001.
2. Engineer-in-Chief (P&ED), Govt. of Mizoram, New Secretariat Complex, Khatla, Aizawl-796001.
3. Director (Dist.), MePDCL, Lumjingshai, Short Round Road, Shillong-793001.
4. Chief General Manager (Comml.), APDCL, Bijuli Bhawan, Paltan Bazar, Guwahati-781 001.
5. Chief Engineer (P), W. E Zone, Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111.
6. Managing Director, MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
7. Chief Engineer (Power), Dept. of Power, Govt. of Nagaland, Kohima-797001.
8. ED (Comml.), NEEPCO, Brookland Compound, Lower New Colony, Shillong-793003.
9. ED, NERLDC, POSOCO, Dongtieh Lower Nongrah, Lapalang, Shillong-793006.
10. GM (Comml.),NHPC, NHPC Office Complex, Sector 33, Faridabad, Haryana-121003
11. Member Secretary, ERPC, 14 Golf Club Road, Tollygunge, Kolkata-700033
12. ED, ERLDC, POSOCO, 14 Golf Club Road, Kolkata-700033
13. CGM (LDC), SLDC Complex, AEGCL, Kahilipara, Guwahati – 781 019
14. ED (Comml), MSPDCL, Secure Office Bldg Complex, 3rd Floor, South Block, Near 2nd MR Gate, Imphal – 01
15. ED (Tech), MSPCL, Keishampat, Imphal-795 001.
16. Suptd. Engineer (SLDC), Deptt. of Power, Govt. of Arunachal Pradesh, Vidyut Bhawan, Itanagar- 791 111
17. Suptd. Engineer (SLDC), MePTCL, Lumjingshai, Shillong-793001
18. Suptd. Engineer (EM), MePDCL, Lumjingshai, Shillong-793001
19. Suptd. Engineer (Comml.), P & E Dept., Khatla, Aizawl- 796001.
20. Suptd. Engineer, MSLDC Circle, P & E Complex, Electric Veng, Aizawl- 796001.
21. Sr. GM (AM), PGCIL, Dongtieh, Lower Nongrah, Lapalang, Shillong-793006
22. Executive Engineer, Elect. Transmission Division, Dimapur, Nagaland.
23. Addl. General Manager, Commercial & System Operation, TSECL, Agartala- 799001.



(अभिजीतअग्रवाल/ Abhijeet Agarwal)
उप निदेशक/Deputy Director
कार्यपालकअभियंता/Executive Engineer
वाणिज्य / Commercial


**Reactive Energy (VArH) Charge Statement
for the period 8/7/2023 to 8/13/2023**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

BENEFICIARY	AMOUNT PAYABLE TO POOL(Rs.)	AMOUNT RECEIVABLE FROM POOL (Rs.)
ARUNACHAL PRADESH	1,68,530	0
ASSAM	0	74,637
MANIPUR	6,034	0
MEGHALAYA	0	4,57,440
MIZORAM	5,287	0
NAGALAND	5,378	0
TRIPURA	0	6,193

REACTIVE ENERGY CHARGE PAYMENT WITH THE BENEFICIARY

RECEIVABLE BENEFICIARY	FROM BENEFICIARY	AMOUNT RECEIVABLE (Rs.)
ARUNACHAL PRADESH	ASSAM	0
ASSAM	ARUNACHAL PRADESH	3,247
ASSAM	MEGHALAYA	6,589
ASSAM	TRIPURA	0
MANIPUR	NAGALAND	0
MEGHALAYA	ASSAM	0
NAGALAND	MANIPUR	0
TRIPURA	ASSAM	0


 कार्यपालक अभियंता Executive Engineer
 ई. ए. ए. ई. ए. N. E. R. P. C.
 बिहार विभाग Min of Power
 नया दिल्ली Govt of India
 110001 Shillong

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH POOL
for the period 8/7/2023 to 8/13/2023

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
ARUNACHAL PRADESH	132kV Ziro-Ranganadi	NP-9704-A	AR-06	53509.4	43.6	53509.4	43.6	0.00	0.00	0	0	0
	132kV Khupi-Balipara	NP-9606-A	AS-55	23188.9	79.8	23131.8	79.8	-20.56	0.00	3,392	0	3,392
	132kV Lekhi-Nirjuli	NP-9665-A	AR-10	1162.8	28046.1	1162.8	27789.1	0.00	-185.04	0	30,532	30,532
	Nirjuli-TRF 1	NP-9661-A	AR-01	460.8	8789.5	460.8	9100.8	0.00	112.07	0	18,491	18,491
	Nirjuli-TRF 2	NP-9662-A	AR-02	557.6	7472.6	557.6	7783.4	0.00	111.89	0	18,462	18,462
	132kV Tenga-Balipara	NP-9696-A	AR-17	42862	6.5	42573	6.5	-208.08	0.00	-34,333	0	-34,333
	132kV Lekhi-Pare	NP-9607-A	PA-01	58725.3	365.6	58725.3	996.2	0.00	302.69	0	49,944	49,944
	132kV Chimpu-Pare	NP-9411-A	PA-05	2892.2	9918.9	2892.2	99788.6	0.00	-62.54	0	-10,320	-10,320
132kV ITANAGAR - BNC FDR 1	NP-9935-A	AR-19	813	98824.1	813	98241	0.00	-559.78	0	92,363	92,363	
TOTAL												1,68,530

ASSAM	220kV BTPS-II - SALAKATI	NP-9070-A	AS-15	21697.7	99830.6	21610.4	99830.6	-139.68	0.00	-23,047	0	-23,047
	220kV BTPS-I - SALAKATI	NP-8476-A	AS-16	33329.6	99550.3	33223.8	99550.3	-169.28	0.00	-27,931	0	-27,931
	220kV SAMAGURI-I - MISA	NP-9583-A	AS-17	94304	98594.6	94304	98594.6	0.00	0.00	0	0	0
	220kV SAMAGURI-II - MISA	NP-9713-A	AS-18	13283.3	99206.1	13284.4	99206.1	1.10	0.00	182	0	182
	220kV SONABIL-BALIPARA	NP-9487-A	AS-42	38527.6	64	38530	64	3.84	0.00	-634	0	-634
	220kV MARIANI - MISA	NP-9700-A	AS-04	0	0	0	0	0.00	0.00	0	0	0
	132kV PANCHGRAM-B'PUR(PG)	NP-6872-A	AS-07	5803.7	79845.6	5723.7	79845.6	-57.60	0.00	-9,504	0	-9,504
	132kV P'pool-JIRIBAM	NE-0039-A	MN-06	8253.2	20	8281.9	20	20.66	0.00	-3,410	0	-3,410
	132kV GOHPUR-NIRJULI	NP-9688-A	AS-13	0	0	0	0	0.00	0.00	0	0	0
	HAFLONG CONSUMPTION	NP-8494-A	AS-11	22014.3	3359.2	22020.4	3359.2	1.10	0.00	-181	0	-181
	132kV HAILAKANDI-SILCHAR-I	NP-5301-A	AS-79	75783.4	91177.1	75769.7	91177.1	-4.93	0.00	-814	0	-814
	132kV HAILAKANDI-SILCHAR 2	NP-9478-A	AS-80	80650.7	99934.4	80639.3	99934.4	-4.10	0.00	-677	0	-677
	132 KV SONABIL-BALIPARA	NP-6150-A	AS-57	5597.8	69869.5	5597.8	69869.5	0.00	0.00	0	0	0
	132kV DEPOTA-BALIPARA	NP-6149-A	AS-56	58011.8	72679.3	58011.8	72679.3	0.00	0.00	0	0	0
	132kV SRIKONA-SILCHAR ckt I	NP-9712-A	AS-77	79655	99980	79639.3	99980	-5.65	0.00	-933	0	-933
	132kV SRIKONA-SILCHAR ckt2	NP-9711-A	AS-78	68667.8	99985.4	68637.2	99985.4	-11.02	0.00	-1,818	0	-1,818
	132kV BOKAJAN-DIMAPUR	NP-9675-A	NG-08	29961.9	1536.3	29961.9	1539.1	0.00	2.69	0	444	444
	400kV AZARA-BONGAIGAON	NP-9983-A	AM-01	92594.8	99743.2	92594.8	99743.2	0.00	0.00	0	0	0
	400kV AZARA-SILCHAR	NP-9981-A	AS-93	1383.2	97603.6	1383.2	97603.6	0.00	0.00	0	0	0
	132kV RANGIA-MOTANGA	NP-9669-A	AS-73	88499.2	94225.6	88528.6	94330	10.58	37.58	1,746	-6,201	-4,455
	220kV Mariani-AGBPP	NP-6888-A	AS-03	0	0	0	0	0.00	0.00	0	0	0
	132kV KARIMGANJ - BADARPUR	NP-9690-A	AM-53	93548.1	98769	93528.9	98769	-13.82	0.00	-2,281	0	-2,281
	132kV KARIMGANJ - KUMARGHAT	NP-9937-A	AM-54	4862.2	5485.1	4862.2	5446	0.00	-28.15	0	4,645	4,645
	132kV Umrangshu - Khandong	NP-5290-A	AM-04	82120.3	98968.5	82450.7	98968.5	158.59	0.00	26,168	0	26,168
	132kV Umrangshu - Haflong	NE-0019-A	AM-05	77578.9	99316.4	77275.9	99316.4	-145.44	0.00	-23,998	0	-23,998
	132kV Pavoi - BNC Ckt I	NP-9680-A	AM-12	15807.4	61112.2	15807.4	61076.7	0.00	-12.78	0	2,109	2,109
	132kV Pavoi - BNC Ckt II	NP-8801-A	AM-13	50316.8	55675	50316.8	55616.2	0.00	-21.17	0	3,493	3,493
	132kV Chapakhowa end of Roing-1	NE-0059-A	AM-67	99997.1	796.2	5.6	1548.1	3.06	270.68	505	-44,663	-44,158
	132kV Chapakhowa end of Roing-2	NE-0056-A	AM-68	99997.7	666.4	4.9	1293.6	2.59	225.79	428	-37,256	-36,828
	132kV GOHPUR END OF BNC	NE-0094-A	AM-61	0	0	0	0	0.00	0.00	0	0	0
	132 KV PARE-N. LAKHIMPUR FDR	NE-0117-A	AM-69	0	99559.6	0	98688.5	0.00	-418.13	0	68,991	68,991
	TOTAL											

MANIPUR	132kV Imp(S)-Imp(PG) Ckt II	NP-9546-A	MN-23	96519.8	99120.3	96519.8	99120.3	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt I	NP-9544-A	ZZ-01	524	99935.4	524	99935.4	0.00	0.00	0	0	0
	JIRIBAM-TRF	NP-8501-A	MN-04	0	0	0	0	0.00	0.00	0	0	0
	132kV JIRIBAM (S) - Jiribam (PG)	NP-9523-A	MN-12	98476.3	99869.3	98479.5	99869.3	1.15	0.00	-190	0	-190
	IMPHAL (PG) ICT I	NP-9520-A	MN-13	22228.1	384.6	22232.2	384.7	1.48	0.04	-244	6	-238
	IMPHAL (PG) ICT II	NP-9522-A	MN-14	19729.3	384.1	19733.6	384.1	1.55	0.00	-255	0	-255
	132kV NINGTHOUKHONG-IMPHAL (PG)	NP-9518-A	MN-10	41819	99419.4	41819	99419.4	0.00	0.00	0	0	0
	132kV Imp(S)-Imp(PG) Ckt III	NP-9689-A	MN-22	93826.5	19.4	93824.5	19.4	-1.44	0.00	238	0	238
	400KV THOUBAL-IMPHAL(PG) 1	NP-9547-A	MN-24	0	0	0	0	0.00	0.00	0	0	0
	400KV THOUBAL-IMPHAL(PG) 2	NP-9543-A	MN-25	2839.9	0.4	2834.5	0.4	-39.27	0.00	6,480	0	6,480
	132kV Tipaimukh end of Aizwal	NE-0169-A	MN-20	0	0	0	0	0.00	0.00	0	0	0
	132kV Tipaimukh end of Jiribam	NE-0167-A	MN-21	0	0	0	0	0.00	0.00	0	0	0
TOTAL												6,034


 Executive Engineer
 NERPC
 Min of Power
 Govt of India
 Shillong

Beneficiary	Line Name	Meter No.	Location ID	MVAR High Day 1	MVAR Low Day 1	MVAR High Day 7	MVAR Low Day 7	Actual*CT*PT		Amount in Rs.		
								MVAR High For Week	MVAR Low For Week	MVAR High Charge	MVAR Low Charge	Net Reactive Charge
MEGHALAYA	132kV KHLRT S-PG	NP-6865-A	ME-02	93758.3	80696.4	93733.2	80696.4	-18.07	0.00	-2,982	0	-2,982
	132kV KHLRT S-PG II	NP-6880-A	ME-09	222	21929.4	226.7	21929.4	3.38	0.00	-558	0	-558
	220kV BYRNIHAT-MISA	NP-9092-A	AS-70	89775.3	85965.8	89775.3	85965.8	0.00	0.00	0	0	0
	220kV BYRNIHAT-MISA II	NP-9091-A	AS-72	83536.4	96033.1	83536.4	96033.1	0.00	0.00	0	0	0
	400kV BYRNIHAT-B'GAON	NP-8370-A	ME-14	96724.5	99953.7	95840	99953.7	-3,216.36	0.00	-5,30,700	0	-5,30,700
	400kV BYRNIHAT-SILCHAR	NP-8371-A	ME-15	26390.1	99864	26518.1	99864	465.45	0.00	76,800	0	76,800
TOTAL												-4,57,440
MIZORAM	132kV LAUNGMUAL-AIZWAL PG	NP-9495-A	MZ-02	455	7687.4	455	7741	0.00	19.30	0	3,184	3,184
	132kV ZUANGTUI-MELRIAT PG	NP-9563-A	MZ-14	70780.7	52739.8	70779.9	52751.3	-0.29	4.14	48	683	731
	132kV KOLASIB-BADARPUR PG	NE-0086-A	MZ-11	330.8	99751.1	330.7	99751.1	-0.04	0.00	-6	0	-6
	132kV KOLASIB-AIZAWL PG	NE-0087-A	MZ-12	533.6	43	542.9	43	6.70	0.00	1,105	0	1,105
	132kV Shimui-Melriat(PG)-I	NP-9493-A	MZ-17	99690.8	99233.9	99690.7	99230.6	-0.04	-1.19	-6	196	190
	132kV Shimui-Melriat(PG)-II	NP-9496-A	MZ-18	99505.6	99272.6	99505.3	99270.9	-0.11	-0.61	-18	101	83
TOTAL												5,287
NAGALAND	132kV DIMAPUR S-PG I	NP-9602-A	NG-01	17218.7	9617.8	17218.7	9633.3	0.00	14.88	0	2,455	2,455
	132kV DIMAPUR S-PG II	NP-9649-A	NG-17	74645.8	4782.3	74645.8	4809.8	0.00	19.80	0	3,267	3,267
	132kV KOHIMA-DIMAPUR PG	NP-8472-A	NG-16	6277.2	98233.5	6277.2	98230.2	0.00	-1.19	0	-196	-196
	132kV M'CHANG S-PG I	NP-9653-A	NG-20	44494.4	4884.1	44494.4	4885	0.00	0.32	0	-53	-53
	132kV M'CHANG S-PG II	NP-9655-A	NG-21	43909.1	4966.9	43909.1	4968.5	0.00	0.58	0	-95	-95
TOTAL												5,378
TRIPURA	132kV PK BARI-KUMARGHAT	NP-6860-A	TR-04	97411.7	84658.5	97411.7	84658.5	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR I	NP-9709-A	TR-15	0	0	0	0	0.00	0.00	0	0	0
	132kV PK BARI-SILCHAR II	NP-9710-A	TR-16	0	0	0	0	0.00	0.00	0	0	0
	132kV Agartala-AGTPP Ckt I	NP-6850-A	TR-01	8502.8	6224.7	8482.2	6224.7	-19.78	0.00	-3,263	0	-3,263
	132kV Agartala-AGTPP Ckt II	NP-6851-A	TR-02	48155.9	93754.4	48155.9	93754.4	0.00	0.00	0	0	0
	132kV SM Nagar-Palatana	NP-8471-A	TR-13	68833.2	72313.2	68833.2	72313.2	0.00	0.00	0	0	0
	132kV BUDHJUNGNAGAR- SM NAGAR (STERLITE)	NP-9893-A	TR-28	7383.3	99970.6	7383.7	99970.6	0.38	0.00	-63	0	-63
	132kV SM NAGAR (TSECL) - SM NAGAR (STERLITE)	NP-9890-A	TR-29	14760.3	26.3	14763.1	26.3	2.69	0.00	-444	0	-444
	132kV PK BARI (TSECL) - PK BARI (STERLITE)	NP-9931-A	TR-24	10565.8	99994.9	10573.4	99994.9	7.30	0.00	-1,204	0	-1,204
	132kV AMBASSA (TSECL) - PK BARI (STERLITE)	NP-9930-A	TR-25	4844.2	99999.8	4851.9	99999.8	7.39	0.00	-1,220	0	-1,220
	132kV PK BARI (TSECL) - AGTCCPP CKT I	NP-9933-A	TR-21	1468.8	99967.2	1468.8	99967.2	0.00	0.00	0	0	0
	132kV PK BARI (TSECL) - AGTCCPP CKT II	NP-9932-A	TR-22	1358.8	99997.1	1358.8	99997.1	0.00	0.00	0	0	0
TOTAL												-6,193

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVARH

2) For reactive energy charge, (-) means receivable by the utility and (+) means payable by the utility.

3) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with IISTS.

4) 'NA' means meter reading not available.


 कार्यवाहक अभियंता Executive Engineer
 त्रिपुरा NERPC
 विद्युत विभाग Min of Power
 जल विभाग Govt of India
 शिलांग Shillong

